

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 F L S L S 1 2 0 0 - 0 0 0 0 0 - 0 0 2 4 1 1 1 1 4 5

LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 27 CAT 28

CON'T

01 L 5 0 5 0 0 0 3 3 5 7 0 1 3 0 9 8 2 3 0 4 0 8 8 2 9

REPORT SOURCE 30 DOCKET NUMBER 34 35 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During normal full power operation the 1A diesel generator failed to start

03 for a surveillance. This event is reportable per Tech. Spec. 3.8.1.1. The

04 D/G was repaired, retested, and returned to service in 62 hrs.; which is

05 within the 72 hrs. permitted by Tech. Spec. During this time the 1B diesel

06 generator was fully operable. The health and safety of the general public

07 was not affected by this event. For previous D/G problems see LER's: 76-21,

08 44; 77-2, 3, 15, 40, 42; 78-36; 79-8, 13, 14, 18, 21, 28, 32; 80-1, 12, 13, 21, 55, 56; 81-38, 47,

09 8

SYSTEM CODE E E 11 CAUSE CODE E 12 CAUSE SUBCODE A 13 COMPONENT CODE I N S T R U 14 COMP SUBCODE X 15 VALVE SUBCODE Z 16

LER/RP REPORT NUMBER 17 8 2 21 22 SEQUENTIAL REPORT NO. 0 1 1 24 25 OCCURRENCE CODE 0 3 28 29 REPORT TYPE L 30 REVISION NO. 0 32

ACTION TAKEN X 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 37 38 ATTACHMENT SUBMITTED N 23 NRC-4 FORM 505 N 24 PRIME CORP SUPPLIER A 25 COMPONENT MANUFACTURER D 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Troubleshooting revealed that the 1A diesel generator speed switch (A16)

11 had failed. The failed Dynalco Model RT2326 is no longer made. It was

12 replaced with the newer Dynalco Model SS2396. Both the vendor and power

13 plant engineering evaluated the substitution as acceptable. The repair was

14 documented by an FRG approved plant/change modification package.

FACILITY STATUS E 23 % POWER 0 9 8 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION Surveillance 32

ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

PERSONNEL EXPOSURES NUMBER 0 37 38 TYPE Z 39 DESCRIPTION NA 40

PERSONNEL INJURIES NUMBER 0 41 42 DESCRIPTION NA 43

LOSS OF OR DAMAGE TO FACILITY TYPE Z 44 DESCRIPTION NA 45

PUBLICITY ISSUED N 46 DESCRIPTION NA 47

NRC USE ONLY

NAME OF PREPARED P. L. Pace

PHONE (305) 552-3654

8204160509 820408
PDR ADOCK 05000335
S PDR