

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

1750 Chestnut Street Tower II

March 30, 1982

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303



Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 2 - DOCKET
NO. 50-260 - FACILITY OPERATING LICENSE DPR-52 - REPORTABLE OCCURRENCE
REPORT BFRO-50-260/82012

The enclosed report provides details concerning a stop valve which would
not remain open rendering high-pressure coolant injection inoperable. This
report is submitted in accordance with Browns Ferry unit 2 Technical
Specification 6.7.2.b(2).

Very truly yours,

TENNESSEE VALLEY AUTHORITY

J. A. Green
J. A. Green
Director of Nuclear Power

Enclosure

cc (Enclosure):

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Records Center
Institute of Nuclear Power Operations
1820 Water Place
Atlanta, Georgia 30339

Mr. R. F. Sullivan, NRC Inspector, Browns Ferry

OFFICIAL COPY

1822
5/11

8204160515 820330
PDR ADDCK 05000260
S PDR