

## CONTROL BLOCK:

0	1	M	I	D	C	C	2	2	0	0	0	0	0	0	0	0	0	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	15	LICENSE NUMBER											25	26	LICENSE TYPE				30	57	CAT	58

CON'T

REPORT SOURCE: 01 L6 U5 00003167 031182 80408829

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | FOLLOWING A UNIT SHUTDOWN, THE CONTAINMENT AIR PARTICULATE AND GASEOUS RADIATION

0 3 | MONITORING SYSTEM (R-11/R-12) SAMPLE PUMP TRIPPED ON LOW FLOW. ATTEMPTS TO RESTART

0 4 | THE SAMPLE PUMP WERE UNSUCCESSFUL, THEREFORE, R-11 AND R-12 WAS DECLARED INOPERABLE

0 5 | AT 1650 HOURS ON MARCH 11, 1982. THE EVENT IS NON-CONSERVATIVE WITH RESPECT TO TECH-

0 6 | NICAL SPECIFICATIONS 3.3.2.1 TABLE 3.3-3, 3.3.3.1 AND 3.4.6.1.

0	7	
0	8	

SYSTEM CODE B B		CAUSE CODE X		CAUSE SUBCODE X		COMPONENT CODE I N S T R U				COMP. SUBCODE E		VALVE SUBCODE Z	
9 10		11 12		12 13		13 14 15 16 17 18				19 20		20 21	
17 LER/RO REPORT NUMBER		EVENT YEAR 8 2		SEQUENTIAL REPORT NO. 0 1 9		OCCURRENCE CODE /		REPORT TYPE L		REVISION NO. 0			
21 22		23 24		24 26		27 28		28 29		30 31		32 33	
ACTION TAKEN E		FUTURE ACTION Z		EFFECT ON PLANT Z		SHUTDOWN METHOD Z		HOURS 0 0 0		ATTACHMENT SUBMITTED N		NPRD-4 FORM SUB. Y	
33 34		35 36		36 37		37 40		41 42		43 44		44 47	
PRIME COMP. SUPPLIER N		COMPONENT MANUFACTURER W 1 2 0											
45 46		47 48		49 50		51 52		53 54		55 56		57 58	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

INVESTIGATION FOUND THE SAMPLE PUMP TRIPPING AT APPROXIMATELY 8 SCFM, WHICH IS THE LOW FLOW TRIP SETPOINT. THE FLOW WAS ADJUSTED TO THE CORRECT LEVEL OF 10 SCFM. THE EXACT CAUSE OF THE LOW FLOW CONDITION COULD NOT BE DETERMINED. THE SAMPLE SYSTEM WAS VERIFIED TO BE OPERATING CORRECTLY AND RETURNED TO SERVICE AT 2230 HOURS ON MARCH 11, 1982. NO FURTHER ACTION IS PLANNED AT THIS TIME.

7 8 9  
FACILITY STATUS 1 5 G 28  
% POWER 10 11 12 0 0 0 29  
OTHER STATUS 13 NA 30  
METHOD OF DISCOVERY 45 B 31  
DISCOVERY DESCRIPTION 46 OPERATOR OBSERVATION 32

ACTIVITY CONTENT  
RELEASED OF RELEASE

1 6 2 9 3 3 4 4

AMOUNT OF ACTIVITY (35)

NA

LOCATION OF RELEASE (36)

NA

PERSONNEL EXPOSURES											
NUMBER			TYPE	DESCRIPTION							
1	7	0	0	0	37	Z	38	NA			39

PERSONNEL INJURIES	
NUMBER	DESCRIPTION
00040	NA

8		9		11		12	
LOSS OF OR DAMAGE TO FACILITY				(43)			
TYPE		DESCRIPTION					
1	9	Z	(42)	NA			

7 8 9 10  
PUBICITY  
ISSUED DEF  
2 0 N 44  
7 8 9 10  
8204160546 820408  
PDR ADCK 05000316  
S  
NRC USE ONLY  
68 69 70

NAME OF PREPARER K. H. FALGOUT

PHONE: 616-465-5901