

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

1750 Chestnut Street Tower II

April 5, 1982

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303



Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 1 - DOCKET
NO. 50-259 - FACILITY OPERATING LICENSE DPR-33 - REPORTABLE OCCURRENCE
REPORT BFRO-50-259/82017

The enclosed report provides details concerning reactor water indicator
LI-3-46A reading 0 inches. This report is submitted in accordance with
Browns Ferry unit 1 Technical Specification 6.7.2.b.2.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

H. J. Green
H. J. Green
Director of Nuclear Power

Enclosure

cc (Enclosure):

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Records Center
Institute of Nuclear Power Operations
1820 Water Place
Atlanta, Georgia 30339

NRC Inspector, Browns Ferry

8204160555 820405
PDR ADOCK 05000259
S PDR

An Equal Opportunity Employer

OFFICIAL COPY

IE 22
5/1