

BALTIMORE GAS AND ELECTRIC COMPANY

P.O. BOX 1475

BALTIMORE, MARYLAND 21203

ARTHUR E. LUNDVALL, JR.
VICE PRESIDENT
SUPPLY

April 8, 1982

Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Mr. Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

SUBJECT: Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 & 2; Docket Nos. 50-317 & 50-318
Request for Amendments



Gentlemen:

Baltimore Gas and Electric Company hereby requests Amendments for Operating Licenses DPR-53 and DPR-69 for Calvert Cliffs Units 1 and 2, respectively, with the submittal of the enclosed proposed changes to the Technical Specifications.

PROPOSED CHANGE

Delete the following sections from Appendix B, Environmental Technical Specifications:

Section 2.1	Thermal Limitation on Condenser Cooling Water Discharge
Section 2.2.1	Dissolved Solids and pH
Section 2.2.2	Treatment Chemicals
Section 3.1	Nonradiological Survey Limits
Section 3.1.1	Abiotic
Section 3.1.2	Biotic
Section 3.1.2.(e)	General Aquatic Ecological Surveys
Section 3.1.2.(a)(1)	Fish Surveys
Section 3.1.2.(a)(2)	Crab Surveys
Section 3.1.2.(a)(3)	Oyster Tray Surveys
Section 3.1.2(b)	Impingement of Organisms
Section 5.6.1(a)	Annual Environmental Monitoring report
	Part A: Nonradiological Report
Section 5.6.2(a)	Nonroutine Environmental Operating Report
Revise Appendix B	Table of Contents

A001
1/1
w/checkbox:
\$4400.00

DISCUSSION AND JUSTIFICATION

As a result of the Yellow Creek Decision (December 27, 1978), water quality requirements are the province of the Environmental Protection Agency through the National Pollutant Discharge Elimination System (NPDES) permit process. We have

April 8, 1982

received a new NPDES permit for operations at Calvert Cliffs issued by the Maryland Department of Health and Mental Hygiene, effective February 3, 1982.

This permit allows a delta T of 12°F and reduces the biological monitoring. The chemical limitations of Section 2.2.1 and 2.2.2 are redundant to the limitations of the NPDES permit and accordingly should be deleted from Appendix B.

We, therefore, request, with this submittal, deletion of the above sections from the Environmental Technical Specifications.

SAFETY COMMITTEE REVIEW

These proposed changes to the Technical Specifications have been reviewed by our Plant Operations and Safety Review and Off-Site Safety Review Committees, and they have concluded that implementation of these changes will not result in an undue risk to the health and safety of the public.

FEE DETERMINATION

We have determined, pursuant to 10 CFR Part 170 Paragraph 170.22, that this Amendment request consists of Class III and Class I amendments for Calvert Cliffs Unit Nos. 1 and 2, respectively, and, accordingly, we are including BG&E Check No. B051325 in the amount of \$4,400.00 to cover the fee for this request.

BALTIMORE GAS AND ELECTRIC COMPANY

By: 

Vice President - Supply

AEL/LOW/gla

STATE OF MARYLAND :**: TO WIT:****CITY OF BALTIMORE :**

Mr. Arthur E. Lundvall, Jr., being duly sworn, states that he is Vice President of the Baltimore Gas and Electric Company, a corporation of the State of Maryland; that he executed the foregoing Amendment for the purpose therein set forth; that the statements made in said Amendment are true and correct to the best of his knowledge, information, and belief; and that he was authorized to execute the Amendment on behalf of said Corporation.

Mr. Robert A. Clark

3

April 8, 1982

Witness my Hand and Notarial Seal:

Ruth H. Grese
Notary Public

My Commission Expires:

July 1, 1982

cc: J. A. Biddison, Esquire
G. F. Trowbridge, Esquire
D. H. Jaffe
R. E. Architzel