

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N C B E P 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T

0 1 L 0 5 0 - 0 3 2 4 0 3 0 1 8 2 0 3 2 6 8 2 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During plant operation while performing Reactor Low Water Level Nos. 2 and 3 Channel

0 3 Functional Test, PT-03.1.7P, low level switch 2-B21-LIS-N031B-2, did not actuate.

0 4 This switch provides one of the actuation signals required to initiate the ADS at a

0 5 reactor level of ≥ 2.5 ". Other redundant instrumentation was operable which would

0 6 have initiated ADS. This event did not affect the health and safety of the public.

0 7 Technical Specifications 3.3.3, 6.9.1.9b

0 8 9 80

0 9 I B 11 E 12 E 13 I N S T R U 14 S 15 Z 16
7 8 9 10 11 12 13 18 19 20

17 LER/RO REPORT NUMBER 8 2 0 4 5 0 3 L 0
21 22 23 24 26 27 28 29 30 31 32

ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
C 18 X 19 Z 20 Z 21 0 0 0 0 N 23 Y 24 N 25 Y 0 1 0 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The switch to actuation magnet adjustment was out of tolerance preventing switch

1 1 actuation. The switch was readjusted and the instrument was calibrated and returned

1 2 to service. The N031B instrument will be replaced with analog instrumentation

1 3 during the scheduled 1982 refueling outage.

1 4 9 80

1 5 E 28 0 8 2 29 NA B 31 Periodic Test
7 8 9 10 12 13 44 45 46 80

1 6 Z 33 Z 34 NA NA
7 8 9 10 11 44 45 80

1 7 0 0 0 37 Z 38 NA
7 8 9 10 11 12 13 80

1 8 0 0 0 40 NA
7 8 9 10 11 12 80

1 9 Z 42 NA
7 8 9 10 80

2 0 8204160577 820316
PDR ADOCK 05000324 PDR
S NA
7 8 9 10 68 69 80

NAME OF PREPARER M. J. Pastva, Jr.

PHONE: (919) 457-9521