

LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N J S G S 2 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 58

CON'T
0 1 REPORT SOURCE L 6 0 5 0 0 0 3 1 1 7 0 6 0 6 8 1 8 0 7 0 6 8 1 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 At 1700 hours, June 6, 1981, during a routine channel check, Pressurizer Pressure
0 3 Channel 1 indicated greater than the maximum allowable tolerance. The channel was
0 4 declared inoperable and the bistables were tripped. Action Statements 3.3.1 and
0 5 3.3.2 were entered. This constituted operation in a degraded mode in accordance
0 6 with Technical Specification 6.9.1.9.b.

0 7
0 8

0 9 SYSTEM CODE I A 11 CAUSE CODE E 12 CAUSE SUBCODE E 13 COMPONENT CODE I N S T R U 14 COMP SUBCODE T 15 VALVE SUBCODE Z 16
7 8 9 10 11 12 13 14 15 16

17 LER/RO REPORT NUMBER 8 1 21 22
18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
E 18 Z 19 Z 20 Z 21 0 0 0 0 Y 23 Y 24 L 25 F 1 2 0 26
33 34 35 36 37 38 39 40 41 42 43 44 45

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 0 Pressure transmitter 2PT455 had drifted out of specification. Pressurizer Pressure
1 1 Channel 1 was recalibrated; tested satisfactorily, and returned to service.
1 2 Action Statements 3.3.1 and 3.3.2 were terminated at 2030 hours, on June 6, 1981.
1 3
1 4

1 5 FACILITY STATUS C 28 % POWER 0 0 0 29 OTHER STATUS N/A 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Operator Observation 32
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 6 ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 NA 35 AMOUNT OF ACTIVITY NA 36 LOCATION OF RELEASE NA 37
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

2 0 PUBLICITY ISSUED N 44 DESCRIPTION NA 45
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

J. J. Espey

PHONE 609-935-0998

8204190161 810706
PDR ADDOCK 05000311
S PDR