



## PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

(215) 841-4500

V. S. BOYER  
SR. VICE PRESIDENT  
NUCLEAR POWER

March 15, 1982

Mr. R. C. Haynes  
Regional Administrator  
U.S. Nuclear Regulatory Commission  
Region I  
631 Park Avenue  
King of Prussia, PA 19406

Dear Mr. Haynes:

This letter is in response to your letter to Philadelphia Electric Company dated December 24 and provides a status report for those activities scheduled for completion by March 1, 1982.

### ITEM 2c

Demonstrate by unannounced drills that additional specified persons in the proposed staffing plan can be onsite in about 60 minutes after initial notification. Records must be kept.

This will be accomplished no later than March 1, 1982.

In order to satisfy the specified requirement, a new procedure ST/EP-15 "Prompt Notification Communication Drill" has been prepared and approved for use. This procedure was implemented on three different occasions --- February 23, 25 and 27 --- to determine estimated response times for specific support personnel. The types of personnel contacted were in the following categories: senior engineers, instrument and control, maintenance, health physics & chemistry, engineers, and operators. By commitment to the Nuclear Regulatory Commission, 23 support personnel were required on site in about 60 minutes.

The drills demonstrated the capacity to satisfy the intent of this requirement. The following table summarizes the results:

TIME DATE	20:30 23rd	19:20 25th	16:00 27th
personnel contacted	28	28	28
personnel responding ≤ 60 minutes	19	22	23
personnel responding ≤ 75 minutes	27	24	26
personnel required	23	23	23

The procedure and detailed drill data are available for inspection.

These drills were conducted using the commercial telephone system. Progress is being made on the installation of a pager system. When this pager system is fully operational, it is expected that the contact time will be significantly reduced. This means that the required complement of support personnel would arrive on site earlier; and, certain other personnel contacted also could be expected in about a 60 minute period specified.

If there are any question or if additional information is required, please don't hesitate to contact us.

Very truly yours,

*V. A. Boyer*

cc: C. J. Cowgill  
Site Inspector