

SOUTH CAROLINA ELECTRIC & GAS COMPANY

POST OFFICE BOX 764

COLUMBIA, SOUTH CAROLINA 29218

T. C. NICHOLS, JR.
VICE PRESIDENT AND GROUP EXECUTIVE
NUCLEAR OPERATIONS

April 8, 1982



Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: Virgil C. Summer Nuclear Station
Docket No. 50/395
Technical Specifications

Dear Mr. Denton:

The tank volumes listed in the March 3, 1982, Revision of the Proof and Review Copy of the Technical Specifications for the Virgil C. Summer Nuclear Station were usable gallons. The volumes have been converted to contained volumes as described in the bases for these Specifications. Also the maximum contained volume has been eliminated for refueling water storage tank because the tank overflow line will prevent overfilling. The affected pages are enclosed.

Please contact Mr. L. D. Shealy, if you have any questions.

Very truly yours,

T. C. Nichols, Jr.

LDS:TCN:lkb

Attachments

cc: V. C. Summer
G. H. Fischer
H. N. Cyrus
T. C. Nichols, Jr.
M. B. Whitaker, Jr.
J. P. O'Reilly
H. T. Babb
D. A. Nauman
C. L. Ligon (NSRC)
W. A. Williams, Jr.
R. B. Clary
O. S. Bradham
A. R. Koon
M. N. Browne
G. J. Braddick
J. C. Ruoff

(w/o attach.)

(w/o attach.)

(w/o attach.)

L. D. Shealy
W. R. Baehr
M. Virgilio
J. L. Skolds
J. B. Knotts, Jr.
B. A. Bursey
J. B. Cookinham
W. F. Kane
NPCF
File

8204190315 820408
PDR ADOCK 05000395
A PDR

13001
5/11