

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

April 13, 1982



Director of Licensing
Attention: Mr. Domenic B. Vassallo, Chief
Operating Reactors Branch No. 2
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Mr. Vassallo:

In the Matter of the) Docket Nos. 50-259
Tennessee Valley Authority) 50-260
50-296

T. A. Ippolito's letter dated September 9, 1981 and R. J. Clark's letter dated March 29, 1982 to H. G. Parris transmitted Amendment Nos. 75, 72, and 52 to Facility Licenses DPR-33, -52, and -68. These amendments changed the technical specifications of Browns Ferry Nuclear Plant to reflect a modified electrical distribution system. The Safety Evaluation Report attached to these amendments committed TVA to test and verify the results of analyses performed demonstrating the adequacy of the electrical distribution system voltages.

This letter is to confirm discussions with the NRC staff on January 4 and April 13, 1982 in which it was agreed that TVA need only test the "worst case" condition, i.e., that supply and path which demonstrated the lowest voltages in the analyses. TVA currently plans to perform this testing during the upcoming unit 2 cycle 4 outage.

If you have any questions, please get in touch with us through the Browns Ferry Project Manager.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills
L. M. Mills, Manager

Nuclear Regulation and Safety

Subscribed and sworn to before
me this 13th day of April 1982.

Paulette H. White
Notary Public

My Commission Expires 9-5-84

Enclosure

cc: U.S. Nuclear Regulatory Commission
Region II
ATTN: James P. O'Reilly, Regional Administrator
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

A015
s
/10