



# THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 5000 ■ CLEVELAND, OHIO 44101 ■ TELEPHONE (216) 622-9800 ■ ILLUMINATING BLDG. ■ 55 PUBLIC SQUARE

*Serving The Best Location in the Nation*

Dalwyn R. Davidson  
VICE PRESIDENT  
SYSTEM ENGINEERING AND CONSTRUCTION

April 19, 1982



Mr. A. Schwencer  
Chief, Licensing Branch No. 2  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Perry Nuclear Power Plant  
Docket Nos. 50-440; 50-441  
Operational Q. A. Program

Dear Mr. Schwencer:

This letter and the enclosed information is submitted to provide further clarification to our responses of March 26, 1982, regarding the items covered by our operational quality assurance program.

Please advise us if we can be of any further assistance.

Very Truly Yours,

*Dalwyn R. Davidson*

Dalwyn R. Davidson  
Vice President  
System Engineering and Construction

DRD: mlb

cc: John Stefano  
Max Gildner  
Jay Silberg, Esq.  
Jack Sprahl

*Bas  
5/11*

8204210100 820419  
PDR ADOCK 05000440  
A PDR

Response

The following item responses have been revised since our March 26, 1982 submittal. The item responses listed below supercede our earlier responses.

- a.19            There are no foundations for seismic category 1 electrical duct banks and manholes. The safety-related duct banks and manholes are constructed of reinforced concrete, backed by seismic category 1 fill, and will be added to Item XXXIV.
- a.20            The site grading is not safety-related; however, major modifications to final plant site grading which could significantly affect site drainage will be subject to the pertinent requirements of the operational quality assurance program.
- C.4  
II.B.3            The post-accident sampling system design has not been finalized, but it is not required to be safety-grade. Surveillance testing and system operation will be controlled in accordance with plant operating procedures. (See NOTE 1)
- C.21  
III.A.1.2        Emergency support facilities are not safety-grade and are not included in Table 3.2-1. The emergency response facilities equipment and applicable documentation is controlled in accordance with the pertinent requirements of the operational quality assurance program. (See NOTE 1)
- C.22  
III.D.3.3        Inplant  $I_2$  radiation monitoring equipment is not safety-grade and will not be included in Table 3.2-1. The use of this equipment will be controlled in accordance with plant operating procedures. (See NOTE 1)