



UNITED STATES DEPARTMENT OF COMMERCE  
National Bureau of Standards  
Washington, D.C. 20234



April 12, 1982

Mr. James R. Miller, Chief  
Standardization & Special  
Projects Branch  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555

Dear Mr. Miller:

Subject: NBSR Inner and Outer Plenna Check-Valves, Docket No. 50-184,  
License No. TR-5

This is to confirm our recent understanding regarding the above subject check-valves. As a result of discussions with you and Mr. Bernard and your visits to the NBS reactor facility, it was concluded that the inner and outer plenna check-valves should be removed. It was also determined with your concurrence that the removal of the check-valves comes under the provisions of 10 CFR 50.59 and that prior authorization of the NRC is not required.

Sincerely,

*Robert S. Carter*

Robert S. Carter  
Chief, Reactor Radiation Division

A020  
s  
1/0