

## LICENSEE EVENT REPORT

CONTROL BLOCK: 

--	--	--	--	--	--

 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 M I I D C C 2 0 0 0 0 0 0 0 0 0 0 0 3 4 1 1 1 1 4 5  
7 d 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T

REPORT SOURCE: 0 1 7 8 L 6 0 5 0 0 0 3 1 6 7 0 3 1 5 8 2 8 0 4 1 3 8 2 9  
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES	
02	WHILE IN MODE 5, SURVEILLANCE TESTING OF THE ENGINEERED SAFETY FEATURE VENTILATION

03 | SYSTEM FILTER TRAIN (HV-AES-2) REVEALED THAT ONE HEPA FILTER DID NOT MEET THE AIR

04 | FLOW DISTRIBUTION CRITERIA AS SPECIFIED IN TECHNICAL SPECIFICATIONS 4.7.6.1.d.2.








05 \_\_\_\_\_

0	6	
---	---	--

0	7	
---	---	--

0	8
---	---

7	8	9	SYSTEM	CAUSE	CAUSE	COMP	VALVE
1	2	3	4	5	6	7	8

(17) LER/RO REPORT NUMBER 8 2 — 0 2 1 / 0 3 L — 0

ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS				ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER			
C	18	Z	19	Z	20	Z	21	0	0	0	0	N	23	Y	24	N	25	A	2	2	0
32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1	0	ALL NEW HEPA FILTERS WERE INSTALLED, A RETEST WAS PERFORMED AND FOUND TO BE SATIS-
---	---	--

1 1 | FACTORY. THE HEPA FILTER THAT DID NOT MEET THE FLOW CRITERIA WAS EXAMINED AND NO

CAUSE FOR FAILURE WAS EVIDENT BY VISUAL INSPECTION. THE FILTER HAD BEEN TESTED ON

PREVIOUS OCCASIONS AND FOUND TO BE SATISFACTORY. NO FURTHER ACTION IS PLANNED AT

THIS TIME.

7 8 9

FACILITY STATUS (1) 5 (28) G  
% POWER (29) 0 0 0 0  
OTHER STATUS (30) NA  
METHOD OF DISCOVERY (31) B  
DISCOVERY DESCRIPTION (32) SURVEILLANCE TEST

ACTIVITY CONTENT  
RELEASED OF RELEASE

1 6 7 33 10 34

AMOUNT OF ACTIVITY (35)

NA

LOCATION OF RELEASE (36)

NA

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	Z	(38)	NA	(39)

PERSONNEL INJURIES		DESCRIPTION	
NUMBER			
1	0	0	NA

8		9		11		12	
TYPE		LOSS OF OR DAMAGE TO FACILITY DESCRIPTION					
1	9	Z	42	NA			

7 8 9 10  
PUBLICATION  
ISSUED DESCRIPTION (45)  
2 0 N (44) NA 8204220357 820413  
PDR ADOCK 05000316  
S PDR  
NRC USE ONLY  
7 8 9 10 68 69 8

NAME OF PREPARER R. A. PALMER

PHONE: 616-465-5901