

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261



R. H. LEASBURG
VICE PRESIDENT
NUCLEAR OPERATIONS

April 16, 1982

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
Attn: Mr. Robert A. Clark, Chief
Operating Reactors Branch No. 3
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Serial No. 228
NO/JHL:acm
Docket Nos. 50-338
50-339
License Nos. NPF-4
NPF-7

Gentlemen:

AMENDMENT TO OPERATING LICENSES NPF-4 AND NPF-7
NORTH ANNA POWER STATION UNIT NOS. 1 AND 2
PROPOSED TECHNICAL SPECIFICATION CHANGE

Pursuant to 10 CFR 50.90, the Virginia Electric and Power Company requests an amendment, in the form of changes to the Technical Specifications, to Operating Licenses NPF-4 and NPF-7 for the North Anna Power Station, Unit Nos. 1 and 2. The proposed changes are enclosed.

The proposed change exempts North Anna Unit Nos. 1 and 2 from the requirement to perform functional testing for large snubbers greater than 50,000 kips, around the steam generators and reactor coolant pumps, during the upcoming refueling and maintenance outages. The proposed change will prevent personnel radiation exposure and allow the current refueling and maintenance schedules to remain unchanged. The restart of North Anna Unit No. 2 is scheduled for May 14, 1982 and the restart of North Anna Unit No. 1 is scheduled for July 2, 1982.

Vepco will functionally test a representative sample of large snubbers greater than 50,000 kips each refueling outage and then functionally test all large snubbers greater than 50,000 kips within their seal lifetime.

This request has been reviewed by the Station Nuclear Safety and Operating Committee and the Safety Evaluation and Control staff. It has been determined that this request does not involve an unreviewed safety question.

We have evaluated this request in accordance with the criteria in 10 CFR 170.22. It has been determined that this request requires a Class III amendment fee. Accordingly, a voucher check in the amount of \$4,400 is enclosed in payment of the required fee.

Very truly yours,

R. H. Leasburg
R. H. Leasburg

Aoo!
1/1
w/check:
\$4400.00

8204220366 820416
PDR ADDCK 05000338
PDR

Attachments:

1. Proposed Technical Specification Change - Unit 1
2. Proposed Technical Specification Change - Unit 2
3. Discussion of Proposed Technical Specification Changes
4. Voucher Check No. 18531 for \$4,400

cc: Mr. James P. O'Reilly, Regional Administrator
Office of Inspection and Enforcement
Region II

COMMONWEALTH OF VIRGINIA)
)
CITY OF RICHMOND)

The foregoing document was acknowledged before me, in and for the City and Commonwealth aforesaid, today by W. L. Stewart, who is Manager-Nuclear Operations and Maintenance, of the Virginia Electric and Power Company. He is duly authorized to execute and file the foregoing document in behalf of that Company, and the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 16th day of April, 19 82.

My Commission expires: 2-26, 19 85.

Ann C. McSee
Notary Public

(SEAL)

M004

Vepco

WACHOVIA BANK & TRUST COMPANY N.A.

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA

531

VOID IF NOT CASHED IN 90 DAYS

03301 26 0018531 00000440000

PAY FOUR THOUSAND FOUR HUNDRED AND 00/100 DOLLARS

TO
THE
ORDER
OF UNITED STATES NUCLEAR
REGULATORY COMMISSION
NUCLEAR REG C DC 20555

BK	CHECK NO	DATE	VENDOR NO	AMOUNT
26	18531	04/13/82	3301	\$4,400.00

03301 26 0018531 00000440000

⑈0288092⑈ ⑆053101529⑆ 3608 088819⑈

Ogletree