

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
---	---

REPORT SOURCE

L	6	0	5	0	0	0	2	7	2	7	1	2	2	2	8	1	8	0	4	0	2	8	2	9
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

On December 22, 1981, the bezel indicators for the Boric Acid Storage Tank (BAST) levels dropped to a 10% reading due to a loss of nitrogen header pressure, caused by depletion of the low pressure nitrogen supply. At 1415 hours No. 11 and 12 BAST were declared inoperable and Action Statements 3.1.2.8.a and 3.3.3.7.a table 3.3-11b Action 2 were entered.

08		78		9		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE						COMP. SUBCODE		VALVE SUBCODE		80	
09		78		9		R B 11		A 12		A 13		A C C U M U 14						Z 15		Z 16			
						EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NC.									
17		LER/RO REPORT NUMBER		21		8 1 22		1 2 0 24		0 3 26		X 30		1 32									
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER							
H 18		Z 19		Z 20		Z 21		0 0 0 0 22		Y 23		N 24		N 25		Z 9 9 9 26							
33		34		35		36		37		41		42		43		44							

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The shift supervisor switched the supply to the backup tank which had a pressure of
1 1 50 PSIG. The BAST level indicators were restored, but due to the low nitrogen
1 2 pressure, were considered unreliable. The high pressure nitrogen backup supply was
1 3 then connected through a regulator to the indicator bubblers. At 1835 hours, proper
1 4 BAST level indication was restored, the BAST's were declared operable, and Action
7 8 9 Statements 3.1.2.8.a and 3.3.3.7.a table 3.3-11b Action 2 were terminated.

FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)

1 5 E (28) 0 6 6 (29) N/A (31) Loss of Indication (32)

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 Z 33 Z 34

AMOUNT OF ACTIVITY (35)

N/A

LOCATION OF RELEASE (36)

N/A

PERSONNEL EXPOSURES									
NUMBER				TYPE	DESCRIPTION				
1	7	0	0	0	(37) Z	(38)	N/A		

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	8	0	0	0	40 N/A

8		9		11		12	
LOSS OF OR DAMAGE TO FACILITY				(43)			
TYPE		DESCRIPTION					
1	9	Z	(42)	N/A			

PUBLICATION		ISSUED		DESCRIPTION		NRC USE ONLY	
2	0	N	(44)	N/A			

NRC USE ONLY

Frank Dickey

PHONE: 609-935-0998