



**PUBLIC
SERVICE
INDIANA**

S. W. Shields
Senior Vice President
Nuclear Division

Mr. James G. Keppler
Regional Administrator
U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

April 7, 1982
S81-18



Docket Nos.: STN 50-546
STN 50-547
Construction Permit Nos.:
CPPR - 170
CPPR - 171

Marble Hill Nuclear Generating Station - Units 1 and 2

Dear Mr. Keppler:

On December 8, 1981, Mr. T. D. Geib of Public Service Company of Indiana, Inc. (PSI) notified your office of a potentially reportable item as required by 10 CFR 50.55(e). PSI Quality Assurance personnel discovered that existing procedures did not require that specification/design changes made via engineering change notices, specification amendments, or drawing revisions be contractually imposed on suppliers or contractors. This created the potential for specification/design changes to be left unincorporated in the as-built configuration of safety related equipment or structures.

PSI is presently determining what, if any, design changes were left unincorporated in final as-built configurations. PSI will adopt procedural modifications which will ensure that specification/design changes are contractually imposed on suppliers and contractors. This letter is intended to fulfill the requirements of an interim report as defined in 10 CFR 50.55(e). A further report will be filed on or before August 16, 1982. If you have any questions on this matter, please feel free to contact me.

Sincerely,

S. W. Shields

TDG/cjk

cc: Director of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

J. E. Konklin
J. J. Harrison

8204220545 820407
PDR ADOCK 05000546
S PDR

P. O. Box 190, New Washington, Indiana 47162

APR 9 1982

812 289 3000

IE27%