

ARIZONA



PUBLIC SERVICE COMPANY

P. O. BOX 21666 • PHOENIX, ARIZONA 85036

April 7, 1982

ANPP-20651-GHD/BSK

U. S. Nuclear Regulatory Commission
Region V
Creskide Oaks Office Park
1450 Maria Lane - Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. T. W. Bishop, Chief
Reactor Construction and
Engineering Support Branch

Subject: Interim Report - DER 82-8
A 50.55(e) Potentially Reportable Deficiency Relating to
GE Switchgear Has Parts Not Certified by Subsuppliers for
Nuclear Use
File: 82-029-026
D.4.33.2

Reference: Telephone Conversation between T. Bishop and G. Duckworth
on March 11, 1982

Dear Sir:

The NRC was notified of a potentially reportable deficiency in the
referenced telephone conversation. At that time, it was estimated that
a determination of reportability would be made within thirty (30) days.

Due to the extensive investigation and evaluation required, an Interim
Report is attached. It is now expected that this information will be
finalized by June 22, 1982, at which time a complete report will be sub-
mitted.

Very truly yours,

E. E. Van Brunt, Jr.
APS Vice President
Nuclear Projects
ANPP Project Director

EEVBJr/GHD:skc

Attachment

cc: See Attached Page 2

8204280 257
S

1E27
S/1
82-87

U. S. Nuclear Regulatory Commission
Attention: Mr. T. W. Bishop, Chief
ANPP-20651-GHD/BSK
April 7, 1982
Page 2

cc: Richard DeYoung, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

J. A. Roedel
D. B. Fasnacht
G. C. Andognini
A. C. Rogers
B. S. Kaplan
W. E. Ide
J. Vorees
J. A. Brand
A. C. Gehr
W. J. Stubblefield
W. G. Bingham
R. L. Patterson
R. W. Welcher
R. M. Grant
D. R. Hawkinson
L. E. Vorderbrueggen

R. L. Greenfield
Assistant Attorney General
Bataan Memorial Building
Santa Fe, New Mexico 87503

Ms. Patricia Lee Hourihan
6413 South 26th Street
Phoenix, Arizona 85040

INTERIM REPORT - DER 82-8
POTENTIAL REPORTABLE DEFICIENCY
ARIZONA PUBLIC SERVICE COMPANY (APS)
PVNGS UNITS 1, 2 AND 3

I. Potential Problem

Section 4.12.3 of Specification 13-EM-009 requires the supplier to certify that the equipment has been manufactured in compliance with an applicable QA program and that the equipment meets the requirements of the procurement documents.

Section 5A.4.3 requires the supplier to initiate Supplier Deviation Disposition Requests so that the project is informed of and participates in all deviations.

Contrary to the above, installed components to switchgear equipment supplied and certified by General Electric to Purchase Order 13-EM-009 were later identified by General Electric as not in compliance with the specification because vendors supplying component parts to General Electric refused to certify certain parts for Nuclear use.

II. Approach To and Status Of Proposed Resolution

Bechtel has requested assistance from General Electric in evaluating and dispositioning this item.

III. Projected Completion of Corrective Action and Submittal of the Final Report

Evaluation of this condition and submittal of the Final Report are forecast to be completed by June 22, 1982.