

Georgia Power Company  
333 Piedmont Avenue  
Atlanta, Georgia 30308  
Telephone 404 525-7893

Mailing Address:  
Post Office Box 4845  
Atlanta, Georgia 30302

February 10, 1982

G. F. Head  
Senior Vice President  
Power Generation

U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region II - Suite 3100  
101 Marietta Street, NW  
Atlanta, Georgia 30303

REFERENCE:  
RII: JPO  
50-321/50-366  
I&E Bulletin  
79-01B



ATTENTION: Mr. James P. O'Reilly

GENTLEMEN:

In accordance with the requirements of I&E Bulletin 79-01B, "Environmental Qualification of Electrical Equipment", Supplement 3, dated October 24, 1980, and in keeping with our desire to keep the NRC supplied with current information, Georgia Power Company hereby submits the attached Revision 4 to the response for Plant Hatch - Units 1 and 2.

This revision reflects the change in qualification status of certain Limitorque motor operated valves from qualified to open item, based on Limitorque's letter dated September 1, 1981. Additionally 2P52-PS N002, 2P52-MOV F565 and associated electrical equipment are being added as a result of a check of the Emergency Operating Procedures review equipment list.

Current progress in the qualification or replacement of the equipment in the report is not reflected in this revision. Through periodic letters, GPC will continue to keep you informed of our qualification/replacement progress. These changes will be reflected in a later revision of the "Environmental Qualification of Class 1E Electrical Equipment" submittal.

If you have any further questions, please contact this office.

G. F. Head states that he is Vice President of Georgia Power Company and is authorized to execute this oath on behalf of Georgia Power Company, and that to the best of his knowledge and belief the facts set forth in this letter are true.

GEORGIA POWER COMPANY

By: G. F. Head  
G. F. Head

Sworn to and subscribed before me this 10th day of February, 1982.

Mae H. Battle

Notary Public, Georgia, State at Large  
My Commission Expires Sept. 20, 1983

Notary Public

BDW/mb  
Enclosure

8204230 374

xc: M. Manry  
R. F. Rogers, III  
J. P. O'Reilly, (NRC - Region II)

IE11510