

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

April 9, 1982

U.S. Nuclear Regulatory Commission
Region II
ATTN: James P. O'Reilly, Regional Administrator
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303



Dear Mr. O'Reilly:

OFFICE OF INSPECTION AND ENFORCEMENT BULLETIN 80-25 - RII:JPO 50-259,
-260, -296 - BROWNS FERRY NUCLEAR PLANT

Please reference my letters to you dated March 18 and July 23, 1981 on the above subject. This letter constitutes our summary of the testing performed on the Browns Ferry unit 3 safety/relief valves. The one valve (SN 1018) to be tested on unit 3 was functionally tested at Wyle Laboratories during the unit 3 cycle 4 refueling outage. The valve actuated properly. No further testing or investigation is planned. This completes our report on the subject bulletin. If you have any questions, please call Jim Domer at FTS 858-2725.

To the best of my knowledge, I declare the statements contained herein are complete and true.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills
L. M. Mills, Manager

Nuclear Regulation and Safety

cc: Mr. R. C. DeYoung, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

8204280 382

Q