



Carolina Power & Light Company

USNRC REGION I
ATLANTA, GEORGIA

MAR 05 1982

02 MAR 11 AM 10:00

Mr. James P. O'Reilly, Director
Region II
United States Nuclear Regulatory Commission
101 Marietta Street, N.W.
Atlanta, GA 30303



SHEARON HARRIS NUCLEAR POWER PLANT
UNIT NOS. 1 AND 2
DOCKET NOS. 50-400 AND 50-401
IE BULLETIN 80-03

Dear Mr. O'Reilly:

By letter dated April 1, 1980, Carolina Power & Light Company (CP&L) responded to IE Bulletin 80-03 and committed at that time to inspect future shipments of charcoal adsorber cells for the specified deficiencies. It was also stated that six units had been received and inspected with no deficiencies noted.

CP&L is satisfied that the problems described in IE Bulletin 80-03 for tray type adsorber cells are not common to the hopper type of charcoal beds used at Shearon Harris and intends to discontinue the charcoal cell inspection program.

Yours very truly,

S. R. Zimmerman

Manager

Licensing & Permits

GSC/lr (7141)

cc: Mr. D. Ward (NRC)
Mr. J. P. O'Reilly (NRC-RII)

8204230384

Q

IE11510