

CONTROL BLOCK:

--	--	--	--	--	--	--

 (1)

0	1	N	Y	J	A	F	1	2	0	0	-	0	0	0	0	-	0	0	0	3	4	1	1	1	1	4			5
7	8	9						14						25						30						57		58	
		LICENSEE CODE						LICENSE NUMBER						LICENSE TYPE															

REPORT SOURCE L 6 0 5 0 0 0 3 3 3 7 0 1 1 7 8 1 8 0 4 1 5 8 2 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

0 2 During normal shutdown, while conducting snubber surveillance to satisfy TS 4.6.1, it was discovered that eight (8) snubbers associated with control rod insert and withdrawal lines had never been subjected to surveillance during earlier inspections. None of the snubbers had been included in TS Table 3.6-1. Functional test of the snubbers was completed with satisfactory results. No significant hazard existed.

0 3

0 4

0 5

0 6

0 7

0 8

80

SYSTEM CODE Z Z (11)		CAUSE CODE A (12)		CAUSE SUBCODE X (13)		COMPONENT CODE Z Z Z Z Z Z Z (14)		COMP. SUBCODE Z (15)		VALVE SUBCODE Z (16)	
EVENT YEAR 8 1 (17)		SEQUENTIAL REPORT NO. 0 1 1 (18)		OCCURRENCE CODE 0 3 (19)		REPORT TYPE X (20)		REVISION NO. 1 (21)			
ACTION TAKEN C (22)		FUTURE ACTION Z (23)		EFFECT ON PLANT Z (24)		SHUTDOWN METHOD Z (25)		HOURS 0 0 0 0 (26)		ATTACHMENT SUBMITTED N (27)	
NPRD-4 FORM SUB. N (28)		PRIME COMP. SUPPLIER Z (29)		COMPONENT MANUFACTURER Z 9 9 9 (30)							

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (31)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 An administrative error was the cause in that the snubbers had not been identified
1 1 as components that require listing in TS Table 3.6-1. Snubbers were replaced
1 2 with operable spares and have been added to the list of those requiring inspection.
1 3 A complete review of the snubber program has been completed and a TS Amendment has
1 4 been submitted to correct TS Table 3.6-1.

8 9
FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)

1 5 G (28) 0 0 0 (29) NA B (31) Surveillance

7 8 9 10 11 12 13 14 15 16 17 18 19 20

ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

1 6 Z (33) Z (34) NA

7 8 9 10 11 12 13 14 15 16 17 18 19 20

PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)

1 7 0 0 0 (37) Z (38) NA

7 8 9 10 11 12 13 14 15 16 17 18 19 20

PERSONNEL INJURIES NUMBER DESCRIPTION (41)

1 8 0 0 0 (40) NA

7 8 9 10 11 12 13 14 15 16 17 18 19 20

LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION (43)

1 9 Z (42) NA

7 8 9 10 11 12 13 14 15 16 17 18 19 20

PUBLICITY ISSUED DESCRIPTION (45)

2 0 N (44) NA

7 8 9 10 11 12 13 14 15 16 17 18 19 20

8204230007 NRC USE ONLY

68 69

NRC USE ONLY

(315) 342-3840 X207