



GPU Nuclear
P.O. Box 388
Forked River, New Jersey 08731
609-693-6000
Writer's Direct Dial Number:

April 20, 1982

Mr. Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555



Dear Mr. Eisenhut:

Subject: Post-TMI Requirements (Generic
Letter No. 82-05)

As requested by the subject correspondence of March 17, 1982, and pursuant to 50.54 (f) of the NRC Regulations, we are supplying you with the current status of the applicable NUREG 0737 items. You will note that on the attachment (Table 1), we have included completion dates or the proposed time of completion. In addition we have referenced correspondence previously sent to you which provides our justification and compensatory measures taken in the interim while requesting deferment of several items.

This completes our response to Generic Letter 82-05. If you should have any further questions please call Mr. James Knubel, Manager, BWR Licensing at (201) 299-2264.

Sincerely,

P. B. Fiedler
Vice President & Director
Oyster Creek

PBF:BH/kdk

Enclosure

Sworn and subscribed to before me this 20th day of April, 1982.

Notary Public

8204260135

GPU Nuclear is a part of the General Public Utilities System

A046
S.11

TABLE 1STATUS OF NUREG 0737 ITEMS

<u>0737 Item</u>	<u>Subject</u>	<u>Status</u>	<u>Correspondence/ Justification</u>
1) I.A.3.1	Simulator Exams	Done by NRC	
2) II.B.2	Plant Shielding	To be Completed during upcoming refueling outage	Reference Letter Dated 12-24-81, P.R. Clark to NRC
3) II.B.3	Postaccident Sampling	Requested Deferral Until Cycle 11 Outage	Reference Letter Dated 12-24-81
4) II.B.4	Training for Mitigating Core Damage	Completed January, 1982	
5) II.E.4.2	Containment Isolation Dependability	Requested Deferral Until Cycle 11 Outage	Reference Letter Dated 8-27-81, also 12-24-81 & 2-10-81
6) II.F.1	(1) Install Noble Gas Effluent Monitors	To be completed during upcoming refueling outage	Reference 12-24-81 Letter to NRC
	(2) Provide capability for effluent monitoring of iodine	To be completed during upcoming refueling outage	Reference 12-24-81 Letter to NRC
	(3) Install in-containment radiation- level monitors	Requested Deferral until Cycle 11 outage	Reference 12-24-81 Letter to NRC

STATUS OF NUREG 0737 ITEMS - PAGE 2

<u>0737 Item</u>	<u>Subject</u>	<u>Status</u>	<u>Correspondence/ Justification</u>
6) II.F.1 Cont.	(4) Provide Continuous indication of containment pressure	To be completed during upcoming refueling outage	Reference 12-24-81 Letter to NRC
	(5) Provide continuous indication of containment water level	To be completed during upcoming refueling outage	Reference 12-24-81 Letter to NRC
	(6) Provide continuous indication of Hydrogen concentration in containment	To be completed during upcoming refueling outage	Reference 12-24-81 Letter to NRC
7) II.K.2.10	Safety Grade Trip	N/A to Oyster Creek	
8) II.K.3.15	Isolation of HPCI and RCIC Modifica- tion.	N/A to Oyster Creek	
9) II.K.3.19	Interlock of Recirc Pump	Requested Deferral Until Cycle 11 Outage	Reference 12-24-81 Letter to NRC
10) II.K.3.22	RCIC Suction	N/A to Oyster Creek	
11) II.K.3.24	Space Cooling for HPCI/RCIC	N/A to Oyster Creek	
12) II.K.3.27	Common Reference Level	Completed 12-31-80	Reference Corres- pondence to NRC dated 6-23-80, 9-26-80, and 2-10-81