

PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

SHIELDS L. DALTROFF
VICE PRESIDENT
ELECTRIC PRODUCTION

(215) 841-5001

June 8, 1982

Docket Nos. 50-277
50-278

Mr. Darrell G. Eisenhut, Director
Division of Licensing
US Nuclear Regulatory Commission
Washington, DC 20555


SUBJECT: 1981 Annual Report on Safety-Relief Valve
Challenges at Peach Bottom Atomic Power Station

Dear Mr. Eisenhut:

This represents the second annual report on safety-relief valve challenges for the Peach Bottom Atomic Power Station as required by NRC Action Plan, Item II.K.3.3. The definition of challenges used to compile this report is the opening of the main steam safety or relief valves in response to a high reactor pressure condition. During 1981, there were no challenges to the primary coolant system safety and relief valves on Peach Bottom Units 2 and 3.

Should you have any questions regarding this matter, please do not hesitate to contact us.

Very truly yours,



cc: C. J. Cowgill - Site Inspector

A046

8206110219 820608
PDR ADDCK 05000277
R PDR