



Nuclear Division  
P.O. Box 4  
Shippingport, PA 15077-0004

Telephone (412) 456-6000

June 2, 1982  
ND1SS1:587

Beaver Valley Power Station, Unit No. 1  
Docket No. 50-334, License No. DPR-66  
LER 82-14/01P

Mr. R. C. Haynes, Regional Administrator  
United States Nuclear Regulatory Commission  
Region 1  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Dear Mr. Haynes:

In accordance with Appendix A, Beaver Valley Technical Specification 6.9.1.8, Administrative Controls, Licensee Event Report LER 82-14/01P is submitted. This occurrence was reported to Mr. W. M. Troskoski, the BVPS NRC Resident Inspector at 1345 hours on June 1, 1982.

While performing the last stage of the records update of the analysis that was required by IE Bulletin 79-14, Stone and Webster has identified and informed Duquesne Light of a postulated overstress condition within the structural support framework for Excess Letdown Heat Exchanger, [CH-E-4]. The function of [CH-E-4] is as an alternate letdown flow path for seal injection water in the event that the normal letdown path becomes inoperable and to assist during normal operations.

A brace was added between two structural support members to eliminate the overstress. The work was performed through Design Change Package 305 during the present refueling and design modification outage.

Additional details will be submitted in the fourteen day follow-up report.

Very truly yours,

H. P. Williams

md

8206110276 820602  
PDR ADOCK 05000334  
S PDR

IE29

Mr. R. C. Haynes  
June 2, 1982  
NDISSI:587  
Page 2

cc: Director Of Management & Program Analysis  
United States Nuclear Regulatory Commission  
Washington, D. C. 20555

J. Hultz, Ohio Edison

Director, Office of Inspection and Enforcement Headquarters  
United States Nuclear Regulatory Commission  
Washington, D. C. 20555

W. J. Ross, BVPS Licensing Project Manager  
United States Nuclear Regulatory Commission  
Washington, D. C. 20555

W. M. Troskoski, Nuclear Regulatory Commission, BVPS Site Inspector

Mr. Alex Timme, CAPCO Nuclear Projects Coordinator, Toledo Edison

Records Center, Institute of Nuclear Power Operations, Atlanta, Georgia

G. E. Muckle, Factory Mutual Engineering, Pittsburgh

Arthur Alford, Stone & Webster/Boston

Mr. John Alford, PA Public Utilities Commission, Harrisburg, PA