



CHARLES CENTER • P. O. BOX 1475 • BALTIMORE, MARYLAND 21203

June 4, 1982

ARTHUR E. LUNDVALL, JR.

VICE PRESIDENT

SUPPLY

Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attn: Mr. D. G. Eisenhower, Director
Division of Licensing

Subject: Calvert Cliffs Nuclear Power Plant
Units Nos. 1 & 2; Dockets Nos. 50-317 & 50-318
Post-TMI Requirements

References: (a) Letter from D. G. Eisenhower to All Licensees of
Operating Reactors dated 5/5/82 (Generic Letter 82-10)
(b) Letter from A. E. Lundvall, Jr. to D. G. Eisenhower
dated 4/19/82.

Gentlemen:

Reference (a) requested detailed schedule information on
TMI-related items. Our response is provided as an enclosure to this
letter. We also wish to confirm that reference (b) is applicable to both
Units 1 and 2 (Dockets Nos. 50-317 and 50-318).

If you have any further questions on this subject, please do
not hesitate to contact us.

BALTIMORE GAS & ELECTRIC COMPANY

By:

A. E. Lundvall, Jr.
A. E. Lundvall, Jr.
Vice President - Supply

STATE OF MARYLAND:

: TO WIT:

CITY OF BALTIMORE:

Arthur E. Lundvall, Jr., being duly sworn states that he is
Vice President of the Baltimore Gas and Electric Company, a Corporation of
the State of Maryland; that he executed the foregoing for the purposes
therein set forth; that the statements made therein are true and correct
to the best of his knowledge, information, and belief; and that he was
authorized to execute the same on behalf of said Corporation.

WITNESS My Hand and Notarial Seal:

8206140088 820604
PDR ADOCK 05000317
P PDR

Cheryl A. Hopkins
Notary Public

My Commission Expires:

July 1, 1982 *Asst*

D. G. Eisenhut

June 4, 1982
Attachment

RESPONSE TO GENERIC LETTER 82-10
POST-TMI REQUIREMENTS

Item I.A.3.1 Limit Overtime

Our administrative procedures to limit overtime have been modified in accordance with NRC Policy Statements issued by Generic Letter No. 82-02 dated February 8, 1982. We plan to submit a request for amendment to our technical specifications by October 1982.

Item I.A.1.3.2 Minimum Shift Crew

Our shift staffing has been modified to satisfy this requirement. Changes to our technical specifications were issued to us in a letter from D. H. Jaffe to A. E. Lundvall, Jr. dated March 9, 1982.

Item I.C.1 Revise Emergency Procedures
We expect to satisfy the schedule requirements of this item.

Item II.D.1.2 Relief Valve and Safety Valve Test Programs

Our current position on this item was provided in our letter from A. E. Lundvall, Jr. to R. A. Clark dated April 6, 1982.

Item III.A.1.2 Staffing Levels for Emergency Situations

Our program to provide for augmentation of staffing in emergency situations has been established as reported in our letters from A. E. Lundvall, Jr. to R. A. Clark dated August 10, 1981 and to R. C. Haynes dated November 16, 1981.

Item III.A.1.2 Upgrade Emergency Support Facilities

Our Technical Support Center and Operational Support Center are operational and our Emergency Operations Facility (EOF) is scheduled to be completed by the end of 1983. Our Interim EOF is equipped to allow company personnel to perform those functions necessary to implement our Response Plan.

Item III.A.2.2 Meteorological Data

Milestones 1 through 6 as set forth in NUREG-0737 have been completed as described in our letter from A. E. Lundvall, Jr. to R. A. Clark dated December 31, 1981.

Item III.D.3.4 Control Room Habitability

Action in response to this item was completed as reported in our letter from C. H. Poindexter to D. G. Eisenhut dated December 30, 1980.

Mr. D. G. Eisenhut

- 2 -

June 4, 1982

cc: J. A. Biddison, Esquire
G. F. Trowbridge, Esquire
Messrs. D. H. Jaffe - NRC
R. E. Architzel - NRC