

PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

(215) 841-4502

MAY 28 1982

JOHN S. KEMPER
VICE-PRESIDENT
ENGINEERING AND RESEARCH

Mr. Ronald C. Haynes, Director
United States Nuclear Regulatory Commission
Office of Inspection and Enforcement, Region I
631 Park Avenue
King of Prussia, PA 19406

Subject: US NRC IE Region I Letter dated February 4, 1982
RE: Site Inspection of December 1, 1981 - January 8, 1982
Inspection Report 50-352/81-17 & 353/81-15
Limerick Generating Station - Units 1 & 2

Reference: Philadelphia Electric Company Letter to the NRC, dated
March 5, 1982

File: QUAL 1-2-2 (352/81-17 & 353/81-15)

Dear Mr. Haynes:


The corrective action noted in the referenced response is being expanded as follows:

The violation identified a pipe spool with a ground out area with wall thickness below code required minimum. It has been determined that Texas Pipe Bending Company was responsible for the problem since the ground out area was under their shop paint. In order to provide further assurance that no other similar conditions exist, the sample inspection previously reported is being expanded.

A sample of approximately 125 pipe spools supplied by Texas Pipe is being selected for inspection. This number (125 spools) has been selected from the MIL-STD-105D.

The sample inspection will be completed and the results reviewed and evaluated by July 28, 1982.

Sincerely,



FJC/mmk

Director of Inspection and Enforcement
United States Nuclear Regulatory Commission
Washington, DC 20555

J. P. Durr, USNRC Resident Inspector

8206150172 820607
PDR ADOCK 05000352
Q PDR

COMMONWEALTH OF PENNSYLVANIA :

ss.

COUNTY OF PHILADELPHIA :

JOHN S. KEMPER, being first duly sworn, deposes and says:

That he is Vice President of Philadelphia Electric Company, the holder of Construction Permits CPPR-106 and CPPR-107 for Limerick Generating Station Units 1 and 2; that he has read the foregoing letter providing additional information relating to the Company's Response to Inspection Report No. 50-352/81-17 and 50-353/81-15 and knows the contents thereof; and that the statements and matters set forth therein are true and correct to the best of his knowledge, information and belief.

John S. Kemper

Subscribed and sworn to before me this 28th day
of May, 1982

Patricia D. Scholl
Notary Public

PATRICIA D. SCHOLL
Notary Public, Philadelphia, Philadelphia Co.
My Commission Expires February 10, 1988