

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to EMERGENCY PLAN ACTIVATION AND CONDITION CLASSIFICATION Instruction or Procedure No. PMP 2080 EPP 001 Revision No. 2</p>	TEMPORARY SHEET NO. TP-1 Page 1 of 2
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u></p> <p>REVISE SECTION 4.3 TO READ AS FOLLOWS:</p> <p style="margin-left: 40px;">4.3 Classify the Emergency Condition, using Exhibit A, according to the highest classification (Unusual Event, Alert, Site Emergency or General Emergency) the condition exceeds.</p> <p style="margin-left: 40px;">4.3.1 In the event of an Alert:</p> <p style="margin-left: 80px;">4.3.1.1 Activation (via Step 4.4 below) of the Technical Support Center and Operations Staging Area is required.</p> <p style="margin-left: 40px;">4.3.2 In the event of a Site Emergency:</p> <p style="margin-left: 80px;">4.3.2.1 Sound the Nuclear Emergency Alarm (NEA)</p> <p style="margin-left: 80px;">4.3.2.2 Follow the NEA with a P.A. announcement indicating whether or not personnel are to evacuate.</p> <p style="margin-left: 80px;">4.3.2.3 Activate (via Step 4.4 below) the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Opera- tions Facility.</p> <p style="margin-left: 40px;">4.3.3 In the event of a General Emergency:</p> <p style="margin-left: 80px;">4.3.3.1 Sound the Nuclear Emergency Alarm (NEA)</p>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u></p> <p>Originator: <u>Richard Bevan</u></p> <p>Management Staff: <u>Richard Bevan</u></p> <p>Senior Reactor Operator: <u>P. C. Craig</u></p> <p>PNSRC: <u>Ed Tumbly</u> Date <u>6-2-82</u></p> <p>Plant Manager: <u>Ed Tumbly</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to EMERGENCY PLAN ACTIVATION AND CONDITION CLASSIFICATION Instruction or Procedure No. PMP 2080 EPP 001 Revision No. 2</p>	<p>TEMPORARY SHEET NO. TP-1 Page 2 of 2</p>
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u>.</p> <div style="margin-left: 100px;"><p>4.3.3.2 Follow the NEA with a P.A. announcement indicating whether or not personnel are to evacuate.</p><p>4.3.3.3 Recommend the Berrien County Sheriff's Department and Michigan State Police consider the following protective actions, as a minimum:</p><div style="margin-left: 40px;"><p>4.3.3.3.1 Activation of the Siren Warning System</p><p>4.3.3.3.2 Sheltering within a two-mile radius and five miles downwind</p><p>4.3.3.3.3 Placing cows within ten miles on stored feed, if appropriate</p></div><p>4.3.3.4 Activation (via Step 4.4 below) of the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility is required.</p></div>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u> Originator: <u>Robert Began</u> Management Staff: <u>Robert Began</u> Senior Reactor Operator: <u>P. C. Craig</u> PNSRC: <u>[Signature]</u> Date <u>6-2-82</u> Plant Manager: <u>E. J. Towner</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____ Distribution: _____</p>

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to RESPONSIBILITIES OF THE ON-SITE Instruction or Procedure No. EMERGENCY COORDINATOR PMP 2080 EPP 015 Revision No. 1</p>	<p>TEMPORARY SHEET NO.</p> <p>TP-1 Sheet 1 of 2</p>
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u>.</p> <p>REVISE EXHIBIT A, <u>ALERT</u>, STEP 5.4 TO READ AS FOLLOWS:</p> <p style="margin-left: 40px;">5.4 Activate the Technical Support Center and Operations Staging Area.</p> <p>REVISE EXHIBIT A, <u>SITE EMERGENCY</u>, STEP 5.4 TO READ AS FOLLOWS:</p> <p style="margin-left: 40px;">5.4 Activate the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility.</p> <p style="margin-left: 80px;">5.4.1 Sound the Nuclear Emergency Alarm and follow with a P.A. announcement indicating whether or not personnel are to evacuate.</p> <p>REVISE EXHIBIT A, <u>GENERAL EMERGENCY</u>, STEP 5.4 TO READ AS FOLLOWS:</p> <p style="margin-left: 40px;">5.4 Activate the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility.</p> <p style="margin-left: 80px;">5.4.1 Sound the Nuclear Emergency Alarm and follow with a P. A. announcement indicating whether or not personnel are to evacuate.</p> <p>REVISE EXHIBIT A, <u>GENERAL EMERGENCY</u>, STEP 5.11 TO READ AS FOLLOWS:</p> <p style="margin-left: 40px;">5.11 Recommend the Berrien County Sheriff's Department and Michigan State Police consider the following protective actions as a minimum:</p>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u></p> <p>Originator: <u>Richard Beggs</u></p> <p>Management Staff: <u>Richard Beggs</u></p> <p>Senior Reactor Operator: <u>P. C. Chang</u></p> <p>PNSRC <u>Blanchard</u> Date <u>6-2-82</u></p> <p>Plant Manager <u>E. L. Torkley</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to RESPONSIBILITIES OF THE ON-SITE EMERGENCY COORDINATOR</p> <p>Instruction or Procedure No. PMP 2080 EPP 015</p> <p>Revision No. 1</p>	<p>TEMPORARY SHEET NO. TP - 1 Sheet 2 of 2</p>
--	---

The following change () new requirement (X) shall be
instituted effective (Date) May 27, 1982.

- 5.11.1 Activation of the Siren Warning System
- 5.11.2 Sheltering within a two-mile radius and five miles downwind
- 5.11.3 Placing cows within ten miles on stored feed, if appropriate

This change should be made a permanent revision to the Instruction or Procedure:

☒ YES ☐ NO ☐ NOT KNOWN, additional review required

<p>Expiration Date: <u>Procedure Revision</u></p> <p>Originator: <u>Michael Bevan</u></p> <p>Management Staff: <u>Michael Bevan</u></p> <p>Senior Reactor Operator: <u>P. C. Cooney</u></p> <p>PNSRC: <u>Ed L. Townsend</u> Date <u>6-2-82</u></p> <p>Plant Manager: <u>Ed L. Townsend</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>
---	--

INDIANA & MICHIGAN POWER COMPANY
DONALD C. COOK NUCLEAR PLANT

PLANT MANAGER PROCEDURE

Index

Identification Number	Title	Revision No. And Date	Comments
PMP 2080 EPP.001	Emergency Plan Activation and Condition Classification	Revision 2 4-27-82	TP-1,5-27-82 Exp NA
EPP.002	Unusual Event	CANCELLED 10-29-81	
EPP.003	Alert	CANCELLED 10-29-81	
EPP.004	Site Emergency	CANCELLED 10-29-81	
EPP.005	General Emergency	CANCELLED 10-29-81	
EPP.006	Initial Dose Assessment (Gaseous)	Rev. 2 4-27-82	
EPP.007	Initial Release Assessments (Liquid)	Revision 0 4-1-81	TP-1,2-23-82 Exp NA
EPP.008	Calling Off-Duty Plant Personnel	Revision 1 4-29-82	TP-1,4-30-82 Exp N/A
EPP.009	Fire Emergency Guidelines	Revision 0 4-1-81	
EPP.010	Toxic Gas Release Guidelines	Revision 0 4-1-81	
EPP.011	Natural Emergency Guidelines	Revision 0 4-1-81	
EPP.012	Initial Off-Site Notification	Revision 1 4-27-82	

INDIANA & MICHIGAN POWER COMPANY
DONALD C. COOK NUCLEAR PLANT

PLANT MANAGER PROCEDURE

Index

Identification Number	Title	Revision No. And Date	Comments
PMP 2080 EPP.013	Duties of the Individual Who Discovers an Emergency Condition	Revision 0 4-1-81	
EPP.014	Personnel Injury	Revision 0 10-27-81	
EPP.015	Responsibility of the On-Site Emergency Coordinator	Revision 1 4-29-82	TP-1,5-27-82 Exp NA
EPP Appendix A	Telephone Numbers for Key Plant Personnel	Revision 2 6-1-82	
EPP Appendix B	Hospital Assistance Plan	Revision 2 3-31-81	
EPP Appendix C	Radiological Supplement	Revision 0 4-1-81	

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to EMERGENCY PLAN ACTIVATION AND CONDITION CLASSIFICATION Instruction or Procedure No. PMP 2080 EPP 001 Revision No. 2</p>	TEMPORARY SHEET NO. TP-1 Page 1 of 2
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u>.</p> <p>REVISE SECTION 4.3 TO READ AS FOLLOWS:</p> <p style="margin-left: 40px;">4.3 Classify the Emergency Condition, using Exhibit A, according to the highest classification (Unusual Event, Alert, Site Emergency or General Emergency) the condition exceeds.</p> <p style="margin-left: 40px;">4.3.1 In the event of an Alert:</p> <p style="margin-left: 80px;">4.3.1.1 Activation (via Step 4.4 below) of the Technical Support Center and Operations Staging Area is required.</p> <p style="margin-left: 40px;">4.3.2 In the event of a Site Emergency:</p> <p style="margin-left: 80px;">4.3.2.1 Sound the Nuclear Emergency Alarm (NEA)</p> <p style="margin-left: 80px;">4.3.2.2 Follow the NEA with a P.A. announcement indicating whether or not personnel are to evacuate.</p> <p style="margin-left: 80px;">4.3.2.3 Activate (via Step 4.4 below) the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility.</p> <p style="margin-left: 40px;">4.3.3 In the event of a General Emergency:</p> <p style="margin-left: 80px;">4.3.3.1 Sound the Nuclear Emergency Alarm (NEA)</p>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u></p> <p>Originator: <u>Alvin Beyer</u></p> <p>Management Staff: <u>Alvin Beyer</u></p> <p>Senior Reactor Operator: <u>P. C. Craig</u></p> <p>PNSRC: <u>Barbara</u> Date <u>6-2-82</u></p> <p>Plant Manager: <u>E. L. Toney</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to EMERGENCY PLAN ACTIVATION AND CONDITION CLASSIFICATION Instruction or Procedure No. PMP 2080 EPP 001 Revision No. 2</p>	TEMPORARY SHEET NO. TP-1 Page 2 of 2
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u>.</p> <div style="margin-left: 100px;"><p>4.3.3.2 Follow the NEA with a P.A. announcement indicating whether or not personnel are to evacuate.</p><p>4.3.3.3 Recommend the Berrien County Sheriff's Department and Michigan State Police consider the following protective actions, as a minimum:</p><div style="margin-left: 40px;"><p>4.3.3.3.1 Activation of the Siren Warning System</p><p>4.3.3.3.2 Sheltering within a two-mile radius and five miles downwind</p><p>4.3.3.3.3 Placing cows within ten miles on stored feed, if appropriate</p></div><p>4.3.3.4 Activation (via Step 4.4 below) of the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility is required.</p></div>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u> Originator: <u>Robert Beggs</u> Management Staff: <u>Robert Beggs</u> Senior Reactor Operator: <u>P.C. Craig</u> PNSRC: <u>[Signature]</u> Date <u>6-2-82</u> Plant Manager: <u>E. J. Towner</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____ Distribution: _____</p>

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to RESPONSIBILITIES OF THE ON-SITE EMERGENCY COORDINATOR Instruction or Procedure No. PMP 2080 EPP 015 Revision No. 1</p>	TEMPORARY SHEET NO. TP-1 Sheet 1 of 2
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u></p> <p>REVISE EXHIBIT A, <u>ALERT</u>, STEP 5.4 TO READ AS FOLLOWS:</p> <p style="padding-left: 40px;">5.4 Activate the Technical Support Center and Operations Staging Area.</p> <p>REVISE EXHIBIT A, <u>SITE EMERGENCY</u>, STEP 5.4 TO READ AS FOLLOWS:</p> <p style="padding-left: 40px;">5.4 Activate the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility.</p> <p style="padding-left: 80px;">5.4.1 Sound the Nuclear Emergency Alarm and follow with a P.A. announcement indicating whether or not personnel are to evacuate.</p> <p>REVISE EXHIBIT A, <u>GENERAL EMERGENCY</u>, STEP 5.4 TO READ AS FOLLOWS:</p> <p style="padding-left: 40px;">5.4 Activate the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility.</p> <p style="padding-left: 80px;">5.4.1 Sound the Nuclear Emergency Alarm and follow with a P. A. announcement indicating whether or not personnel are to evacuate.</p> <p>REVISE EXHIBIT A, <u>GENERAL EMERGENCY</u>, STEP 5.11 TO READ AS FOLLOWS:</p> <p style="padding-left: 40px;">5.11 Recommend the Berrien County Sheriff's Department and Michigan State Police consider the following protective actions as a minimum:</p>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u></p> <p>Originator: <u>Richard Beggs</u></p> <p>Management Staff: <u>Richard Beggs</u></p> <p>Senior Reactor Operator: <u>P. C. Chang</u></p> <p>PNSRC: <u>Blanchard</u> Date <u>6-2-82</u></p> <p>Plant Manager: <u>E. L. Tounky</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to RESPONSIBILITIES OF THE ON-SITE EMERGENCY COORDINATOR Instruction or Procedure No. PMP 2080 EPP 015 Revision No. 1</p>	<p>TEMPORARY SHEET NO. TP - 1 Sheet 2 of 2</p>
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u></p> <div style="margin-top: 20px;"><p>5.11.1 Activation of the Siren Warning System</p><p>5.11.2 Sheltering within a two-mile radius and five miles downwind</p><p>5.11.3 Placing cows within ten miles on stored feed, if appropriate</p></div>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u></p> <p>Originator: <u>Arland Bevan</u></p> <p>Management Staff: <u>Arland Bevan</u></p> <p>Senior Reactor Operator: <u>P. C. Craig</u></p> <p>PNSRC: <u>Barbara</u> Date <u>6-2-82</u></p> <p>Plant Manager: <u>E. L. Townley</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>

INDIANA & MICHIGAN POWER COMPANY
DONALD C. COOK NUCLEAR PLANT

PLANT MANAGER PROCEDURE

Index

Identification Number	Title	Revision No. And Date	Comments
PMP 2080 EPP.001	Emergency Plan Activation and Condition Classification	Revision 2 4-27-82	TP-1,5-27-82 Exp NA
EPP.002	Unusual Event	CANCELLED 10-29-81	
EPP.003	Alert	CANCELLED 10-29-81	
EPP.004	Site Emergency	CANCELLED 10-29-81	
EPP.005	General Emergency	CANCELLED 10-29-81	
EPP.006	Initial Dose Assessment (Gaseous)	Rev. 2 4-27-82	
EPP.007	Initial Release Assessments (Liquid)	Revision 0 4-1-81	TP-1,2-23-82 Exp NA
EPP.008	Calling Off-Duty Plant Personnel	Revision 1 4-29-82	TP-1,4-30-82 Exp N/A
EPP.009	Fire Emergency Guidelines	Revision 0 4-1-81	
EPP.010	Toxic Gas Release Guidelines	Revision 0 4-1-81	
EPP.011	Natural Emergency Guidelines	Revision 0 4-1-81	
EPP.012	Initial Off-Site Notification	Revision 1 4-27-82	

INDIANA & MICHIGAN POWER COMPANY
DONALD C. COOK NUCLEAR PLANT

PLANT MANAGER PROCEDURE

Index

Identification Number	Title	Revision No. And Date	Comments
PMP 2080 EPP.013	Duties of the Individual Who Discovers an Emergency Condition	Revision 0 4-1-81	
EPP.014	Personnel Injury	Revision 0 10-27-81	
EPP.015	Responsibility of the On-Site Emergency Coordinator	Revision 1 4-29-82	TP-1,5-27-82 Exp NA
EPP Appendix A	Telephone Numbers for Key Plant Personnel	Revision 2 6-1-82	
EPP Appendix B	Hospital Assistance Plan	Revision 2 3-31-81	
EPP Appendix C	Radiological Supplement	Revision 0 4-1-81	

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to EMERGENCY PLAN ACTIVATION AND CONDITION CLASSIFICATION Instruction or Procedure No. PMP 2080 EPP 001 Revision No. 2</p>	TEMPORARY SHEET NO. TP-1 Page 1 of 2
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u>.</p> <p>REVISE SECTION 4.3 TO READ AS FOLLOWS:</p> <p style="margin-left: 40px;">4.3 Classify the Emergency Condition, using Exhibit A, according to the highest classification (Unusual Event, Alert, Site Emergency or General Emergency) the condition exceeds.</p> <p style="margin-left: 40px;">4.3.1 In the event of an Alert:</p> <p style="margin-left: 80px;">4.3.1.1 Activation (via Step 4.4 below) of the Technical Support Center and Operations Staging Area is required.</p> <p style="margin-left: 40px;">4.3.2 In the event of a Site Emergency:</p> <p style="margin-left: 80px;">4.3.2.1 Sound the Nuclear Emergency Alarm (NEA)</p> <p style="margin-left: 80px;">4.3.2.2 Follow the NEA with a P.A. announcement indicating whether or not personnel are to evacuate.</p> <p style="margin-left: 80px;">4.3.2.3 Activate (via Step 4.4 below) the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Opera- tions Facility.</p> <p style="margin-left: 40px;">4.3.3 In the event of a General Emergency:</p> <p style="margin-left: 80px;">4.3.3.1 Sound the Nuclear Emergency Alarm (NEA)</p>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u></p> <p>Originator: <u>Richard Bean</u></p> <p>Management Staff: <u>Richard Bean</u></p> <p>Senior Reactor Operator: <u>P. C. Craig</u></p> <p>PNSRC: <u>Barbara</u> Date <u>6-2-82</u></p> <p>Plant Manager: <u>E. L. Tawley</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

This temporary sheet applies to EMERGENCY PLAN ACTIVATION AND CONDITION CLASSIFICATION Instruction or Procedure No. PMP 2080 EPP 001 Revision No. 2	TEMPORARY SHEET NO. TP-1 Page 2 of 2
--	---

The following change () new requirement (X) shall be
instituted effective (Date) May 27, 1982

- 4.3.3.2 Follow the NEA with a P.A. announcement
indicating whether or not personnel are to
evacuate.
- 4.3.3.3 Recommend the Berrien County Sheriff's
Department and Michigan State Police consider
the following protective actions, as a minimum:
 - 4.3.3.3.1 Activation of the Siren Warning System
 - 4.3.3.3.2 Sheltering within a two-mile radius
and five miles downwind
 - 4.3.3.3.3 Placing cows within ten miles on stored
feed, if appropriate
- 4.3.3.4 Activation (via Step 4.4 below) of the Technical
Support Center, Operations Staging Area, Joint
Public Information Center and Emergency Operations
Facility is required.

This change should be made a permanent revision to the Instruction or Procedure:

☒ YES ☐ NO ☐ NOT KNOWN, additional review required

Expiration Date: <u>Procedure Revision</u> Originator: <u>Robert Beggs</u> Management Staff: <u>Robert Beggs</u> Senior Reactor Operator: <u>P. C. Craig</u> PNSRC: <u>Blanchard</u> Date <u>6-2-82</u> Plant Manager: <u>E. J. Townsend</u> Date <u>6-2-82</u>	Standard Dist. List No.: _____ Distribution: _____
--	---

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to RESPONSIBILITIES OF THE ON-SITE EMERGENCY COORDINATOR Instruction or Procedure No. PMP 2080 EPP 015 Revision No. 1</p>	<p>TEMPORARY SHEET NO.</p> <p>TP-1 Sheet 1 of 2</p>
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u>.</p> <p>REVISE EXHIBIT A, <u>ALERT</u>, STEP 5.4 TO READ AS FOLLOWS:</p> <p style="margin-left: 40px;">5.4 Activate the Technical Support Center and Operations Staging Area.</p> <p>REVISE EXHIBIT A, <u>SITE EMERGENCY</u>, STEP 5.4 TO READ AS FOLLOWS:</p> <p style="margin-left: 40px;">5.4 Activate the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility.</p> <p style="margin-left: 80px;">5.4.1 Sound the Nuclear Emergency Alarm and follow with a P.A. announcement indicating whether or not personnel are to evacuate.</p> <p>REVISE EXHIBIT A, <u>GENERAL EMERGENCY</u>, STEP 5.4 TO READ AS FOLLOWS:</p> <p style="margin-left: 40px;">5.4 Activate the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility.</p> <p style="margin-left: 80px;">5.4.1 Sound the Nuclear Emergency Alarm and follow with a P. A. announcement indicating whether or not personnel are to evacuate.</p> <p>REVISE EXHIBIT A, <u>GENERAL EMERGENCY</u>, STEP 5.11 TO READ AS FOLLOWS:</p> <p style="margin-left: 40px;">5.11 Recommend the Berrien County Sheriff's Department and Michigan State Police consider the following protective actions as a minimum:</p>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u></p> <p>Originator: <u>Richard Beggs</u></p> <p>Management Staff: <u>Richard Beggs</u></p> <p>Senior Reactor Operator: <u>P. C. Chang</u></p> <p>PNSRC <u>Bl. Lumsden</u> Date <u>6-2-82</u></p> <p>Plant Manager <u>E. L. Townley</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to <u>RESPONSIBILITIES OF THE ON-SITE</u> <u>EMERGENCY COORDINATOR</u> Instruction or Procedure No. <u>PMP 2080 EPP 015</u> Revision No. <u>1</u></p>	<p>TEMPORARY SHEET NO. TP - 1 Sheet 2 of 2</p>
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u>.</p> <div style="margin-left: 40px;"><p>5.11.1 Activation of the Siren Warning System</p><p>5.11.2 Sheltering within a two-mile radius and five miles downwind</p><p>5.11.3 Placing cows within ten miles on stored feed, if appropriate</p></div>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u> Originator: <u>Michael Beggs</u> Management Staff: <u>Michael Beggs</u> Senior Reactor Operator: <u>P. C. Craig</u> PNSRC <u>Shawnessa</u> Date <u>6-2-82</u> Plant Manager <u>E. L. Towner</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____ Distribution: _____</p>

INDIANA & MICHIGAN POWER COMPANY
DONALD C. COOK NUCLEAR PLANT

PLANT MANAGER PROCEDURE

Index

Identification Number	Title	Revision No. And Date	Comments
PMP 2080 EPP.001	Emergency Plan Activation and Condition Classification	Revision 2 4-27-82	TP-1,5-27-82 Exp NA
EPP.002	Unusual Event	CANCELLED 10-29-81	
EPP.003	Alert	CANCELLED 10-29-81	
EPP.004	Site Emergency	CANCELLED 10-29-81	
EPP.005	General Emergency	CANCELLED 10-29-81	
EPP.006	Initial Dose Assessment (Gaseous)	Rev. 2 4-27-82	
EPP.007	Initial Release Assessments (Liquid)	Revision 0 4-1-81	TP-1,2-23-82 Exp NA
EPP.008	Calling Off-Duty Plant Personnel	Revision 1 4-29-82	TP-1,4-30-82 Exp N/A
EPP.009	Fire Emergency Guidelines	Revision 0 4-1-81	
EPP.010	Toxic Gas Release Guidelines	Revision 0 4-1-81	
EPP.011	Natural Emergency Guidelines	Revision 0 4-1-81	
EPP.012	Initial Off-Site Notification	Revision 1 4-27-82	

INDIANA & MICHIGAN POWER COMPANY
DONALD C. COOK NUCLEAR PLANT

PLANT MANAGER PROCEDURE

Index

Identification Number	Title	Revision No. And Date	Comments
PMP 2080 EPP.013	Duties of the Individual Who Discovers an Emergency Condition	Revision 0 4-1-81	
EPP.014	Personnel Injury	Revision 0 10-27-81	
EPP.015	Responsibility of the On-Site Emergency Coordinator	Revision 1 4-29-82	TP-1,5-27-82 Exp NA
EPP Appendix A	Telephone Numbers for Key Plant Personnel	Revision 2 6-1-82	
EPP Appendix B	Hospital Assistance Plan	Revision 2 3-31-81	
EPP Appendix C	Radiological Supplement	Revision 0 4-1-81	

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to EMERGENCY PLAN ACTIVATION AND CONDITION CLASSIFICATION Instruction or Procedure No. PMP 2080 EPP 001 Revision No. 2</p>	TEMPORARY SHEET NO. TP-1 Page 1 of 2
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u>.</p> <p>REVISE SECTION 4.3 TO READ AS FOLLOWS:</p> <p style="margin-left: 40px;">4.3 Classify the Emergency Condition, using Exhibit A, according to the highest classification (Unusual Event, Alert, Site Emergency or General Emergency) the condition exceeds.</p> <p style="margin-left: 40px;">4.3.1 In the event of an Alert:</p> <p style="margin-left: 80px;">4.3.1.1 Activation (via Step 4.4 below) of the Technical Support Center and Operations Staging Area is required.</p> <p style="margin-left: 40px;">4.3.2 In the event of a Site Emergency:</p> <p style="margin-left: 80px;">4.3.2.1 Sound the Nuclear Emergency Alarm (NEA)</p> <p style="margin-left: 80px;">4.3.2.2 Follow the NEA with a P.A. announcement indicating whether or not personnel are to evacuate.</p> <p style="margin-left: 80px;">4.3.2.3 Activate (via Step 4.4 below) the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility.</p> <p style="margin-left: 40px;">4.3.3 In the event of a General Emergency:</p> <p style="margin-left: 80px;">4.3.3.1 Sound the Nuclear Emergency Alarm (NEA)</p>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u></p> <p>Originator: <u>Andrew Beyer</u></p> <p>Management Staff: <u>Andrew Beyer</u></p> <p>Senior Reactor Operator: <u>P. C. Craig</u></p> <p>PNSRC <u>Blaschke</u> Date <u>6-2-82</u></p> <p>Plant Manager <u>E. L. Tounley</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to EMERGENCY PLAN ACTIVATION AND CONDITION CLASSIFICATION Instruction or Procedure No. PMP 2080 EPP 001 Revision No. 2</p>	TEMPORARY SHEET NO. TP-1 Page 2 of 2
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u>.</p> <div style="margin-left: 40px;"><p>4.3.3.2 Follow the NEA with a P.A. announcement indicating whether or not personnel are to evacuate.</p><p>4.3.3.3 Recommend the Berrien County Sheriff's Department and Michigan State Police consider the following protective actions, as a minimum:</p><div style="margin-left: 40px;"><p>4.3.3.3.1 Activation of the Siren Warning System</p><p>4.3.3.3.2 Sheltering within a two-mile radius and five miles downwind</p><p>4.3.3.3.3 Placing cows within ten miles on stored feed, if appropriate</p></div><p>4.3.3.4 Activation (via Step 4.4 below) of the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility is required.</p></div>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u> Originator: <u><i>Robert Beggs</i></u> Management Staff: <u><i>Robert Beggs</i></u> Senior Reactor Operator: <u><i>P.C. Craig</i></u> PNSRC <u><i>[Signature]</i></u> Date <u>6-2-82</u> Plant Manager <u><i>E.T. [Signature]</i></u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____ Distribution: _____</p>

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to RESPONSIBILITIES OF THE ON-SITE Instruction or Procedure No. EMERGENCY COORDINATOR PMP 2080 EPP 015 Revision No. 1</p>	<p>TEMPORARY SHEET NO.</p> <p>TP-1 Sheet 1 of 2</p>
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u>.</p> <p>REVISE EXHIBIT A, <u>ALERT</u>, STEP 5.4 TO READ AS FOLLOWS:</p> <p style="padding-left: 40px;">5.4 Activate the Technical Support Center and Operations Staging Area.</p> <p>REVISE EXHIBIT A, <u>SITE EMERGENCY</u>, STEP 5.4 TO READ AS FOLLOWS:</p> <p style="padding-left: 40px;">5.4 Activate the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility.</p> <p style="padding-left: 80px;">5.4.1 Sound the Nuclear Emergency Alarm and follow with a P.A. announcement indicating whether or not personnel are to evacuate.</p> <p>REVISE EXHIBIT A, <u>GENERAL EMERGENCY</u>, STEP 5.4 TO READ AS FOLLOWS:</p> <p style="padding-left: 40px;">5.4 Activate the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility.</p> <p style="padding-left: 80px;">5.4.1 Sound the Nuclear Emergency Alarm and follow with a P. A. announcement indicating whether or not personnel are to evacuate.</p> <p>REVISE EXHIBIT A, <u>GENERAL EMERGENCY</u>, STEP 5.11 TO READ AS FOLLOWS:</p> <p style="padding-left: 40px;">5.11 Recommend the Berrien County Sheriff's Department and Michigan State Police consider the following protective actions as a minimum:</p>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u></p> <p>Originator: <u>Richard Bevan</u></p> <p>Management Staff: <u>Richard Bevan</u></p> <p>Senior Reactor Operator: <u>P. C. Chang</u></p> <p>PNSRC <u>Blanchard</u> Date <u>6-2-82</u></p> <p>Plant Manager <u>E. J. Townley</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to RESPONSIBILITIES OF THE ON-SITE EMERGENCY COORDINATOR Instruction or Procedure No. PMP 2080 EPP 015 Revision No. 1</p>	TEMPORARY SHEET NO. TP - 1 Sheet 2 of 2
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u></p> <div style="margin-left: 40px;"><p>5.11.1 Activation of the Siren Warning System</p><p>5.11.2 Sheltering within a two-mile radius and five miles downwind</p><p>5.11.3 Placing cows within ten miles on stored feed, if appropriate</p></div>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u></p> <p>Originator: <u>Arland Byers</u></p> <p>Management Staff: <u>Arland Byers</u></p> <p>Senior Reactor Operator: <u>P. C. Craig</u></p> <p>PNSRC <u>BAH</u> Date <u>6-2-82</u></p> <p>Plant Manager <u>EX Townley</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>

INDIANA & MICHIGAN POWER COMPANY
DONALD C. COOK NUCLEAR PLANT

PLANT MANAGER PROCEDURE

Index

Identification Number	Title	Revision No. And Date	Comments
PMP 2080 EPP.001	Emergency Plan Activation and Condition Classification	Revision 2 4-27-82	TP-1,5-27-82 Exp NA
EPP.002	Unusual Event	CANCELLED 10-29-81	
EPP.003	Alert	CANCELLED 10-29-81	
EPP.004	Site Emergency	CANCELLED 10-29-81	
EPP.005	General Emergency	CANCELLED 10-29-81	
EPP.006	Initial Dose Assessment (Gaseous)	Rev. 2 4-27-82	
EPP.007	Initial Release Assessments (Liquid)	Revision 0 4-1-81	TP-1,2-23-82 Exp NA
EPP.008	Calling Off-Duty Plant Personnel	Revision 1 4-29-82	TP-1,4-30-82 Exp N/A
EPP.009	Fire Emergency Guidelines	Revision 0 4-1-81	
EPP.010	Toxic Gas Release Guidelines	Revision 0 4-1-81	
EPP.011	Natural Emergency Guidelines	Revision 0 4-1-81	
EPP.012	Initial Off-Site Notification	Revision 1 4-27-82	

INDIANA & MICHIGAN POWER COMPANY
DONALD C. COOK NUCLEAR PLANT

PLANT MANAGER PROCEDURE

Index

Identification Number	Title	Revision No. And Date	Comments
PMP 2080 EPP.013	Duties of the Individual Who Discovers an Emergency Condition	Revision 0 4-1-81	
EPP.014	Personnel Injury	Revision 0 10-27-81	
EPP.015	Responsibility of the On-Site Emergency Coordinator	Revision 1 4-29-82	TP-1,5-27-82 Exp NA
EPP Appendix A	Telephone Numbers for Key Plant Personnel	Revision 2 6-1-82	
EPP Appendix B	Hospital Assistance Plan	Revision 2 3-31-81	
EPP Appendix C	Radiological Supplement	Revision 0 4-1-81	

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to EMERGENCY PLAN ACTIVATION AND CONDITION CLASSIFICATION Instruction or Procedure No. PMP 2080 EPP 001 Revision No. 2</p>	TEMPORARY SHEET NO. TP-1 Page 1 of 2
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u>.</p> <p>REVISE SECTION 4.3 TO READ AS FOLLOWS:</p> <p style="margin-left: 40px;">4.3 Classify the Emergency Condition, using Exhibit A, according to the highest classification (Unusual Event, Alert, Site Emergency or General Emergency) the condition exceeds.</p> <p style="margin-left: 40px;">4.3.1 In the event of an Alert:</p> <p style="margin-left: 80px;">4.3.1.1 Activation (via Step 4.4 below) of the Technical Support Center and Operations Staging Area is required.</p> <p style="margin-left: 40px;">4.3.2 In the event of a Site Emergency:</p> <p style="margin-left: 80px;">4.3.2.1 Sound the Nuclear Emergency Alarm (NEA)</p> <p style="margin-left: 80px;">4.3.2.2 Follow the NEA with a P.A. announcement indicating whether or not personnel are to evacuate.</p> <p style="margin-left: 80px;">4.3.2.3 Activate (via Step 4.4 below) the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Opera- tions Facility.</p> <p style="margin-left: 40px;">4.3.3 In the event of a General Emergency:</p> <p style="margin-left: 80px;">4.3.3.1 Sound the Nuclear Emergency Alarm (NEA)</p>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u></p> <p>Originator: <u>Richard Bevan</u></p> <p>Management Staff: <u>Richard Bevan</u></p> <p>Senior Reactor Operator: <u>P. C. Craig</u></p> <p>PNSRC: <u>Barbara</u> Date <u>6-2-82</u></p> <p>Plant Manager: <u>E. L. Trowley</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to EMERGENCY PLAN ACTIVATION AND CONDITION CLASSIFICATION Instruction or Procedure No. PMP 2080 EPP 001 Revision No. 2</p>	<p>TEMPORARY SHEET NO. TP-1 Page 2 of 2</p>
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u>.</p> <div style="margin-left: 100px;"><p>4.3.3.2 Follow the NEA with a P.A. announcement indicating whether or not personnel are to evacuate.</p><p>4.3.3.3 Recommend the Berrien County Sheriff's Department and Michigan State Police consider the following protective actions, as a minimum:</p><div style="margin-left: 40px;"><p>4.3.3.3.1 Activation of the Siren Warning System</p><p>4.3.3.3.2 Sheltering within a two-mile radius and five miles downwind</p><p>4.3.3.3.3 Placing cows within ten miles on stored feed, if appropriate</p></div><p>4.3.3.4 Activation (via Step 4.4 below) of the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility is required.</p></div>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u> Originator: <u>Robert Began</u> Management Staff: <u>Robert Began</u> Senior Reactor Operator: <u>P. C. Craig</u> PNSRC <u>[Signature]</u> Date <u>6-2-82</u> Plant Manager <u>E. J. Townley</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____ Distribution: _____</p>

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

This temporary sheet applies to RESPONSIBILITIES OF THE ON-SITE Instruction or Procedure No. EMERGENCY COORDINATOR PMP 2080 EPP 015 Revision No. 1	TEMPORARY SHEET NO. TP-1 Sheet 1 of 2
--	--

The following change () new requirement (X) shall be
instituted effective (Date) May 27, 1982.

REVISE EXHIBIT A, ALERT, STEP 5.4 TO READ AS FOLLOWS:

5.4 Activate the Technical Support Center and Operations Staging Area.

REVISE EXHIBIT A, SITE EMERGENCY, STEP 5.4 TO READ AS FOLLOWS:

5.4 Activate the Technical Support Center, Operations Staging Area,
Joint Public Information Center and Emergency Operations
Facility.

5.4.1 Sound the Nuclear Emergency Alarm and follow with a
P.A. announcement indicating whether or not personnel
are to evacuate.

REVISE EXHIBIT A, GENERAL EMERGENCY, STEP 5.4 TO READ AS FOLLOWS:

5.4 Activate the Technical Support Center, Operations Staging Area,
Joint Public Information Center and Emergency Operations
Facility.

5.4.1 Sound the Nuclear Emergency Alarm and follow with a
P. A. announcement indicating whether or not personnel
are to evacuate.

REVISE EXHIBIT A, GENERAL EMERGENCY, STEP 5.11 TO READ AS FOLLOWS:

5.11 Recommend the Berrien County Sheriff's Department and Michigan
State Police consider the following protective actions as a minimum:

This change should be made a permanent revision to the Instruction or Procedure:

☒ YES ☐ NO ☐ NOT KNOWN, additional review required

Expiration Date: Procedure Revision
Originator: Richard Beggs
Management Staff: Richard Beggs
Senior Reactor Operator: P. C. Chang
PNSRC Blanchard Date 6-2-82
Plant Manager E. L. Townley Date 6-2-82

Standard Dist. List No.: _____
Distribution: _____

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to RESPONSIBILITIES OF THE ON-SITE EMERGENCY COORDINATOR Instruction or Procedure No. PMP 2080 EPP 015 Revision No. 1</p>	<p>TEMPORARY SHEET NO. TP - 1 Sheet 2 of 2</p>
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u></p> <div style="margin-left: 40px;"><p>5.11.1 Activation of the Siren Warning System</p><p>5.11.2 Sheltering within a two-mile radius and five miles downwind</p><p>5.11.3 Placing cows within ten miles on stored feed, if appropriate</p></div>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u></p> <p>Originator: <u>Arland Byers</u></p> <p>Management Staff: <u>Arland Byers</u></p> <p>Senior Reactor Operator: <u>P. C. Craig</u></p> <p>PNSRC <u>Barbara</u> Date <u>6-2-82</u></p> <p>Plant Manager <u>E. L. Townsend</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>

INDIANA & MICHIGAN POWER COMPANY
DONALD C. COOK NUCLEAR PLANT

PLANT MANAGER PROCEDURE

Index

Identification Number	Title	Revision No. And Date	Comments
PMP 2080 EPP.001	Emergency Plan Activation and Condition Classification	Revision 2 4-27-82	TP-1,5-27-82 Exp NA
EPP.002	Unusual Event	CANCELLED 10-29-81	
EPP.003	Alert	CANCELLED 10-29-81	
EPP.004	Site Emergency	CANCELLED 10-29-81	
EPP.005	General Emergency	CANCELLED 10-29-81	
EPP.006	Initial Dose Assessment (Gaseous)	Rev. 2 4-27-82	
EPP.007	Initial Release Assessments (Liquid)	Revision 0 4-1-81	TP-1,2-23-82 Exp NA
EPP.008	Calling Off-Duty Plant Personnel	Revision 1 4-29-82	TP-1,4-30-82 Exp N/A
EPP.009	Fire Emergency Guidelines	Revision 0 4-1-81	
EPP.010	Toxic Gas Release Guidelines	Revision 0 4-1-81	
EPP.011	Natural Emergency Guidelines	Revision 0 4-1-81	
EPP.012	Initial Off-Site Notification	Revision 1 4-27-82	

INDIANA & MICHIGAN POWER COMPANY
DONALD C. COOK NUCLEAR PLANT

PLANT MANAGER PROCEDURE

Index

Identification Number	Title	Revision No. And Date	Comments
PMP 2080 EPP.013	Duties of the Individual Who Discovers an Emergency Condition	Revision 0 4-1-81	
EPP.014	Personnel Injury	Revision 0 10-27-81	
EPP.015	Responsibility of the On-Site Emergency Coordinator	Revision 1 4-29-82	TP-1,5-27-82 Exp NA
EPP Appendix A	Telephone Numbers for Key Plant Personnel	Revision 2 6-1-82	
EPP Appendix B	Hospital Assistance Plan	Revision 2 3-31-81	
EPP Appendix C	Radiological Supplement	Revision 0 4-1-81	

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to EMERGENCY PLAN ACTIVATION AND CONDITION CLASSIFICATION Instruction or Procedure No. PMP 2080 EPP 001 Revision No. 2</p>	<p>TEMPORARY SHEET NO. TP-1 Page 1 of 2</p>
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u>.</p> <p>REVISE SECTION 4.3 TO READ AS FOLLOWS:</p> <p style="margin-left: 40px;">4.3 Classify the Emergency Condition, using Exhibit A, according to the highest classification (Unusual Event, Alert, Site Emergency or General Emergency) the condition exceeds.</p> <p style="margin-left: 40px;">4.3.1 In the event of an Alert:</p> <p style="margin-left: 80px;">4.3.1.1 Activation (via Step 4.4 below) of the Technical Support Center and Operations Staging Area is required.</p> <p style="margin-left: 40px;">4.3.2 In the event of a Site Emergency:</p> <p style="margin-left: 80px;">4.3.2.1 Sound the Nuclear Emergency Alarm (NEA)</p> <p style="margin-left: 80px;">4.3.2.2 Follow the NEA with a P.A. announcement indicating whether or not personnel are to evacuate.</p> <p style="margin-left: 80px;">4.3.2.3 Activate (via Step 4.4 below) the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility.</p> <p style="margin-left: 40px;">4.3.3 In the event of a General Emergency:</p> <p style="margin-left: 80px;">4.3.3.1 Sound the Nuclear Emergency Alarm (NEA)</p>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u></p> <p>Originator: <u>Donald Bean</u></p> <p>Management Staff: <u>Donald Bean</u></p> <p>Senior Reactor Operator: <u>P. C. Craig</u></p> <p>PNSRC <u>Blanchard</u> Date <u>6-2-82</u></p> <p>Plant Manager <u>E. L. Tounley</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to EMERGENCY PLAN ACTIVATION AND CONDITION CLASSIFICATION Instruction or Procedure No. PMP 2080 EPP 001 Revision No. 2</p>	TEMPORARY SHEET NO. TP-1 Page 2 of 2
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u>.</p> <div style="margin-left: 100px;"><p>4.3.3.2 Follow the NEA with a P.A. announcement indicating whether or not personnel are to evacuate.</p><p>4.3.3.3 Recommend the Berrien County Sheriff's Department and Michigan State Police consider the following protective actions, as a minimum:</p><div style="margin-left: 40px;"><p>4.3.3.3.1 Activation of the Siren Warning System</p><p>4.3.3.3.2 Sheltering within a two-mile radius and five miles downwind</p><p>4.3.3.3.3 Placing cows within ten miles on stored feed, if appropriate</p></div><p>4.3.3.4 Activation (via Step 4.4 below) of the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility is required.</p></div>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u> Originator: <u><i>Robert Beggs</i></u> Management Staff: <u><i>Robert Beggs</i></u> Senior Reactor Operator: <u><i>P.C. Craig</i></u> PNSRC: <u><i>[Signature]</i></u> Date <u><i>6-2-82</i></u> Plant Manager: <u><i>E.T. [Signature]</i></u> Date <u><i>6-2-82</i></u></p>	<p>Standard Dist. List No.: _____ Distribution: _____</p>

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to RESPONSIBILITIES OF THE ON-SITE Instruction or Procedure No. EMERGENCY COORDINATOR PMP 2080 EPP 015 Revision No. 1</p>	<p>TEMPORARY SHEET NO.</p> <p>TP-1 Sheet 1 of 2</p>
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u></p> <p>REVISE EXHIBIT A, <u>ALERT</u>, STEP 5.4 TO READ AS FOLLOWS:</p> <p style="padding-left: 40px;">5.4 Activate the Technical Support Center and Operations Staging Area.</p> <p>REVISE EXHIBIT A, <u>SITE EMERGENCY</u>, STEP 5.4 TO READ AS FOLLOWS:</p> <p style="padding-left: 40px;">5.4 Activate the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility.</p> <p style="padding-left: 80px;">5.4.1 Sound the Nuclear Emergency Alarm and follow with a P.A. announcement indicating whether or not personnel are to evacuate.</p> <p>REVISE EXHIBIT A, <u>GENERAL EMERGENCY</u>, STEP 5.4 TO READ AS FOLLOWS:</p> <p style="padding-left: 40px;">5.4 Activate the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility.</p> <p style="padding-left: 80px;">5.4.1 Sound the Nuclear Emergency Alarm and follow with a P. A. announcement indicating whether or not personnel are to evacuate.</p> <p>REVISE EXHIBIT A, <u>GENERAL EMERGENCY</u>, STEP 5.11 TO READ AS FOLLOWS:</p> <p style="padding-left: 40px;">5.11 Recommend the Berrien County Sheriff's Department and Michigan State Police consider the following protective actions as a minimum:</p>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u></p> <p>Originator: <u>Richard Beggs</u></p> <p>Management Staff: <u>Richard Beggs</u></p> <p>Senior Reactor Operator: <u>P. C. Chang</u></p> <p>PNSRC: <u>Blanchard</u> Date <u>6-2-82</u></p> <p>Plant Manager: <u>E. L. Towner</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to RESPONSIBILITIES OF THE ON-SITE EMERGENCY COORDINATOR Instruction or Procedure No. PMP 2080 EPP 015 Revision No. 1</p>	TEMPORARY SHEET NO. TP - 1 Sheet 2 of 2
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u></p> <div style="margin-left: 40px;"><p>5.11.1 Activation of the Siren Warning System</p><p>5.11.2 Sheltering within a two-mile radius and five miles downwind</p><p>5.11.3 Placing cows within ten miles on stored feed, if appropriate</p></div>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u></p> <p>Originator: <u>Arland Bean</u></p> <p>Management Staff: <u>Arland Bean</u></p> <p>Senior Reactor Operator: <u>P. C. Craig</u></p> <p>PNSRC: <u>BA Hussa</u> Date <u>6-2-82</u></p> <p>Plant Manager: <u>E. L. Townsend</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>

INDIANA & MICHIGAN POWER COMPANY
DONALD C. COOK NUCLEAR PLANT

PLANT MANAGER PROCEDURE

Index

Identification Number	Title	Revision No. And Date	Comments
PMP 2080 EPP.001	Emergency Plan Activation and Condition Classification	Revision 2 4-27-82	TP-1,5-27-82 Exp NA
EPP.002	Unusual Event	CANCELLED 10-29-81	
EPP.003	Alert	CANCELLED 10-29-81	
EPP.004	Site Emergency	CANCELLED 10-29-81	
EPP.005	General Emergency	CANCELLED 10-29-81	
EPP.006	Initial Dose Assessment (Gaseous)	Rev. 2 4-27-82	
EPP.007	Initial Release Assessments (Liquid)	Revision 0 4-1-81	TP-1,2-23-82 Exp NA
EPP.008	Calling Off-Duty Plant Personnel	Revision 1 4-29-82	TP-1,4-30-82 Exp N/A
EPP.009	Fire Emergency Guidelines	Revision 0 4-1-81	
EPP.010	Toxic Gas Release Guidelines	Revision 0 4-1-81	
EPP.011	Natural Emergency Guidelines	Revision 0 4-1-81	
EPP.012	Initial Off-Site Notification	Revision 1 4-27-82	

INDIANA & MICHIGAN POWER COMPANY
DONALD C. COOK NUCLEAR PLANT

PLANT MANAGER PROCEDURE

Index

Identification Number	Title	Revision No. And Date	Comments
PMP 2080 EPP.013	Duties of the Individual Who Discovers an Emergency Condition	Revision 0 4-1-81	
EPP.014	Personnel Injury	Revision 0 10-27-81	
EPP.015	Responsibility of the On-Site Emergency Coordinator	Revision 1 4-29-82	TP-1,5-27-82 Exp NA
EPP Appendix A	Telephone Numbers for Key Plant Personnel	Revision 2 6-1-82	
EPP Appendix B	Hospital Assistance Plan	Revision 2 3-31-81	
EPP Appendix C	Radiological Supplement	Revision 0 4-1-81	

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to EMERGENCY PLAN ACTIVATION AND CONDITION CLASSIFICATION Instruction or Procedure No. PMP 2080 EPP 001 Revision No. 2</p>	TEMPORARY SHEET NO. TP-1 Page 1 of 2
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u>.</p> <p>REVISE SECTION 4.3 TO READ AS FOLLOWS:</p> <p style="margin-left: 40px;">4.3 Classify the Emergency Condition, using Exhibit A, according to the highest classification (Unusual Event, Alert, Site Emergency or General Emergency) the condition exceeds.</p> <p style="margin-left: 40px;">4.3.1 In the event of an Alert:</p> <p style="margin-left: 80px;">4.3.1.1 Activation (via Step 4.4 below) of the Technical Support Center and Operations Staging Area is required.</p> <p style="margin-left: 40px;">4.3.2 In the event of a Site Emergency:</p> <p style="margin-left: 80px;">4.3.2.1 Sound the Nuclear Emergency Alarm (NEA)</p> <p style="margin-left: 80px;">4.3.2.2 Follow the NEA with a P.A. announcement indicating whether or not personnel are to evacuate.</p> <p style="margin-left: 80px;">4.3.2.3 Activate (via Step 4.4 below) the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility.</p> <p style="margin-left: 40px;">4.3.3 In the event of a General Emergency:</p> <p style="margin-left: 80px;">4.3.3.1 Sound the Nuclear Emergency Alarm (NEA)</p>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u></p> <p>Originator: <u>Arland Bean</u></p> <p>Management Staff: <u>Arland Bean</u></p> <p>Senior Reactor Operator: <u>P. C. Craig</u></p> <p>PNSRC: <u>Barbara</u> Date <u>6-2-82</u></p> <p>Plant Manager: <u>E. L. Towner</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

This temporary sheet applies to EMERGENCY PLAN ACTIVATION AND CONDITION CLASSIFICATION Instruction or Procedure No. PMP 2080 EPP 001 Revision No. 2	TEMPORARY SHEET NO. TP-1 Page 2 of 2
--	--

The following change () new requirement (X) shall be
instituted effective (Date) May 27, 1982

- 4.3.3.2 Follow the NEA with a P.A. announcement
indicating whether or not personnel are to
evacuate.
- 4.3.3.3 Recommend the Berrien County Sheriff's
Department and Michigan State Police consider
the following protective actions, as a minimum:
 - 4.3.3.3.1 Activation of the Siren Warning System
 - 4.3.3.3.2 Sheltering within a two-mile radius
and five miles downwind
 - 4.3.3.3.3 Placing cows within ten miles on stored
feed, if appropriate
- 4.3.3.4 Activation (via Step 4.4 below) of the Technical
Support Center, Operations Staging Area, Joint
Public Information Center and Emergency Operations
Facility is required.

This change should be made a permanent revision to the Instruction or Procedure:

☒ YES ☐ NO ☐ NOT KNOWN, additional review required

Expiration Date: <u>Procedure Revision</u> Originator: <u>Noland Bevan</u> Management Staff: <u>Noland Bevan</u> Senior Reactor Operator: <u>P. C. Craig</u> PNSRC <u>[Signature]</u> Date <u>6-2-82</u> Plant Manager <u>E. J. Townsend</u> Date <u>6-2-82</u>	Standard Dist. List No.: _____ Distribution: _____
--	---

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to RESPONSIBILITIES OF THE ON-SITE Instruction or Procedure No. EMERGENCY COORDINATOR PMP 2080 EPP 015 Revision No. 1</p>	<p>TEMPORARY SHEET NO.</p> <p>TP-1 Sheet 1 of 2</p>
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u>.</p> <p>REVISE EXHIBIT A, <u>ALERT</u>, STEP 5.4 TO READ AS FOLLOWS:</p> <p style="padding-left: 40px;">5.4 Activate the Technical Support Center and Operations Staging Area.</p> <p>REVISE EXHIBIT A, <u>SITE EMERGENCY</u>, STEP 5.4 TO READ AS FOLLOWS:</p> <p style="padding-left: 40px;">5.4 Activate the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility.</p> <p style="padding-left: 80px;">5.4.1 Sound the Nuclear Emergency Alarm and follow with a P.A. announcement indicating whether or not personnel are to evacuate.</p> <p>REVISE EXHIBIT A, <u>GENERAL EMERGENCY</u>, STEP 5.4 TO READ AS FOLLOWS:</p> <p style="padding-left: 40px;">5.4 Activate the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility.</p> <p style="padding-left: 80px;">5.4.1 Sound the Nuclear Emergency Alarm and follow with a P. A. announcement indicating whether or not personnel are to evacuate.</p> <p>REVISE EXHIBIT A, <u>GENERAL EMERGENCY</u>, STEP 5.11 TO READ AS FOLLOWS:</p> <p style="padding-left: 40px;">5.11 Recommend the Berrien County Sheriff's Department and Michigan State Police consider the following protective actions as a minimum:</p>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u></p> <p>Originator: <u>Richard Begon</u></p> <p>Management Staff: <u>Richard Begon</u></p> <p>Senior Reactor Operator: <u>P. C. Cray</u></p> <p>PNSRC <u>Blanchard</u> Date <u>6-2-82</u></p> <p>Plant Manager <u>E. L. Townley</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to RESPONSIBILITIES OF THE ON-SITE EMERGENCY COORDINATOR Instruction or Procedure No. PMP 2080 EPP 015 Revision No. 1</p>	TEMPORARY SHEET NO. TP - 1 Sheet 2 of 2
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u></p> <div style="margin-left: 40px;"><p>5.11.1 Activation of the Siren Warning System</p><p>5.11.2 Sheltering within a two-mile radius and five miles downwind</p><p>5.11.3 Placing cows within ten miles on stored feed, if appropriate</p></div>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u></p> <p>Originator: <u>Arland Bevan</u></p> <p>Management Staff: <u>Arland Bevan</u></p> <p>Senior Reactor Operator: <u>P. C. Craig</u></p> <p>PNSRC: <u>BA Hussa</u> Date <u>6-2-82</u></p> <p>Plant Manager: <u>EL Townsend</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>

INDIANA & MICHIGAN POWER COMPANY
DONALD C. COOK NUCLEAR PLANT

PLANT MANAGER PROCEDURE

Index

Identification Number	Title	Revision No. And Date	Comments
PMP 2080 EPP.001	Emergency Plan Activation and Condition Classification	Revision 2 4-27-82	TP-1,5-27-82 Exp NA
EPP.002	Unusual Event	CANCELLED 10-29-81	
EPP.003	Alert	CANCELLED 10-29-81	
EPP.004	Site Emergency	CANCELLED 10-29-81	
EPP.005	General Emergency	CANCELLED 10-29-81	
EPP.006	Initial Dose Assessment (Gaseous)	Rev. 2 4-27-82	
EPP.007	Initial Release Assessments (Liquid)	Revision 0 4-1-81	TP-1,2-23-82 Exp NA
EPP.008	Calling Off-Duty Plant Personnel	Revision 1 4-29-82	TP-1,4-30-82 Exp N/A
EPP.009	Fire Emergency Guidelines	Revision 0 4-1-81	
EPP.010	Toxic Gas Release Guidelines	Revision 0 4-1-81	
EPP.011	Natural Emergency Guidelines	Revision 0 4-1-81	
EPP.012	Initial Off-Site Notification	Revision 1 4-27-82	

INDIANA & MICHIGAN POWER COMPANY
DONALD C. COOK NUCLEAR PLANTPLANT MANAGER PROCEDUREIndex

Identification Number	Title	Revision No. And Date	Comments
PMP 2080 EPP.013	Duties of the Individual Who Discovers an Emergency Condition	Revision 0 4-1-81	
EPP.014	Personnel Injury	Revision 0 10-27-81	
EPP.015	Responsibility of the On-Site Emergency Coordinator	Revision 1 4-29-82	TP-1,5-27-82 Exp NA
EPP Appendix A	Telephone Numbers for Key Plant Personnel	Revision 2 6-1-82	
EPP Appendix B	Hospital Assistance Plan	Revision 2 3-31-81	
EPP Appendix C	Radiological Supplement	Revision 0 4-1-81	

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

This temporary sheet applies to EMERGENCY PLAN ACTIVATION AND CONDITION CLASSIFICATION Instruction or Procedure No. PMP 2080 EPP 001 Revision No. 2	TEMPORARY SHEET NO. TP-1 Page 1 of 2
--	---

The following change () new requirement (X) shall be
instituted effective (Date) May 27, 1982.

REVISE SECTION 4.3 TO READ AS FOLLOWS:

4.3 Classify the Emergency Condition, using Exhibit A, according to the highest classification (Unusual Event, Alert, Site Emergency or General Emergency) the condition exceeds.

4.3.1 In the event of an Alert:

4.3.1.1 Activation (via Step 4.4 below) of the Technical Support Center and Operations Staging Area is required.

4.3.2 In the event of a Site Emergency:

4.3.2.1 Sound the Nuclear Emergency Alarm (NEA)

4.3.2.2 Follow the NEA with a P.A. announcement indicating whether or not personnel are to evacuate.

4.3.2.3 Activate (via Step 4.4 below) the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility.

4.3.3 In the event of a General Emergency:

4.3.3.1 Sound the Nuclear Emergency Alarm (NEA)

This change should be made a permanent revision to the Instruction or Procedure:

☒ YES ☐ NO ☐ NOT KNOWN, additional review required

Expiration Date: Procedure Revision
Originator: Arland Beyer
Management Staff: Arland Beyer
Senior Reactor Operator: P. C. Craig
PNSRC Basham Date 6-2-82
Plant Manager E. L. Townley Date 6-2-82

Standard Dist. List No.: _____
Distribution: _____

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to EMERGENCY PLAN ACTIVATION AND CONDITION CLASSIFICATION Instruction or Procedure No. PMP 2080 EPP 001 Revision No. 2</p>	TEMPORARY SHEET NO. TP-1 Page 2 of 2
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u></p> <div style="margin-left: 150px;"><p>4.3.3.2 Follow the NEA with a P.A. announcement indicating whether or not personnel are to evacuate.</p><p>4.3.3.3 Recommend the Berrien County Sheriff's Department and Michigan State Police consider the following protective actions, as a minimum:</p><div style="margin-left: 40px;"><p>4.3.3.3.1 Activation of the Siren Warning System</p><p>4.3.3.3.2 Sheltering within a two-mile radius and five miles downwind</p><p>4.3.3.3.3 Placing cows within ten miles on stored feed, if appropriate</p></div><p>4.3.3.4 Activation (via Step 4.4 below) of the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility is required.</p></div>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u></p> <p>Originator: <u>Arland Began</u></p> <p>Management Staff: <u>Arland Began</u></p> <p>Senior Reactor Operator: <u>P. C. Craig</u></p> <p>PNSRC: <u>[Signature]</u> Date <u>6-2-82</u></p> <p>Plant Manager: <u>E. J. Townsend</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to RESPONSIBILITIES OF THE ON-SITE Instruction or Procedure No. EMERGENCY COORDINATOR PMP 2080 EPP 015 Revision No. 1</p>	<p>TEMPORARY SHEET NO.</p> <p>TP-1 Sheet 1 of 2</p>
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u>.</p> <p>REVISE EXHIBIT A, <u>ALERT</u>, STEP 5.4 TO READ AS FOLLOWS:</p> <p style="margin-left: 40px;">5.4 Activate the Technical Support Center and Operations Staging Area.</p> <p>REVISE EXHIBIT A, <u>SITE EMERGENCY</u>, STEP 5.4 TO READ AS FOLLOWS:</p> <p style="margin-left: 40px;">5.4 Activate the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility.</p> <p style="margin-left: 80px;">5.4.1 Sound the Nuclear Emergency Alarm and follow with a P.A. announcement indicating whether or not personnel are to evacuate.</p> <p>REVISE EXHIBIT A, <u>GENERAL EMERGENCY</u>, STEP 5.4 TO READ AS FOLLOWS:</p> <p style="margin-left: 40px;">5.4 Activate the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility.</p> <p style="margin-left: 80px;">5.4.1 Sound the Nuclear Emergency Alarm and follow with a P. A. announcement indicating whether or not personnel are to evacuate.</p> <p>REVISE EXHIBIT A, <u>GENERAL EMERGENCY</u>, STEP 5.11 TO READ AS FOLLOWS:</p> <p style="margin-left: 40px;">5.11 Recommend the Berrien County Sheriff's Department and Michigan State Police consider the following protective actions as a minimum:</p>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u></p> <p>Originator: <u>Richard Beggs</u></p> <p>Management Staff: <u>Richard Beggs</u></p> <p>Senior Reactor Operator: <u>D C Chang</u></p> <p>PNSRC: <u>Blanchard</u> Date <u>6-2-82</u></p> <p>Plant Manager: <u>E L Townley</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

This temporary sheet applies to RESPONSIBILITIES OF THE ON-SITE Instruction or Procedure No. EMERGENCY COORDINATOR PMP 2080 EPP 015 Revision No. 1	TEMPORARY SHEET NO. TP - 1 Sheet 2 of 2
--	--

The following change () new requirement (X) shall be
instituted effective (Date) May 27, 1982.

- 5.11.1 Activation of the Siren Warning System
- 5.11.2 Sheltering within a two-mile radius and five miles downwind
- 5.11.3 Placing cows within ten miles on stored feed, if appropriate

This change should be made a permanent revision to the Instruction or Procedure:

☒ YES ☐ NO ☐ NOT KNOWN, additional review required

Expiration Date: <u>Procedure Revision</u> Originator: <u>Arland Beyer</u> Management Staff: <u>Arland Beyer</u> Senior Reactor Operator: <u>P. C. Craig</u> PNSRC <u>BA Hussa</u> Date <u>6-2-82</u> Plant Manager <u>EL Townley</u> Date <u>6-2-82</u>	Standard Dist. List No.: _____ Distribution: _____
---	---

INDIANA & MICHIGAN POWER COMPANY
DONALD C. COOK NUCLEAR PLANT

PLANT MANAGER PROCEDURE

Index

Identification Number	Title	Revision No. And Date	Comments
PMP 2080 EPP.001	Emergency Plan Activation and Condition Classification	Revision 2 4-27-82	TP-1,5-27-82 Exp NA
EPP.002	Unusual Event	CANCELLED 10-29-81	
EPP.003	Alert	CANCELLED 10-29-81	
EPP.004	Site Emergency	CANCELLED 10-29-81	
EPP.005	General Emergency	CANCELLED 10-29-81	
EPP.006	Initial Dose Assessment (Gaseous)	Rev. 2 4-27-82	
EPP.007	Initial Release Assessments (Liquid)	Revision 0 4-1-81	TP-1,2-23-82 Exp NA
EPP.008	Calling Off-Duty Plant Personnel	Revision 1 4-29-82	TP-1,4-30-82 Exp N/A
EPP.009	Fire Emergency Guidelines	Revision 0 4-1-81	
EPP.010	Toxic Gas Release Guidelines	Revision 0 4-1-81	
EPP.011	Natural Emergency Guidelines	Revision 0 4-1-81	
EPP.012	Initial Off-Site Notification	Revision 1 4-27-82	

INDIANA & MICHIGAN POWER COMPANY
DONALD C. COOK NUCLEAR PLANTPLANT MANAGER PROCEDUREIndex

Identification Number	Title	Revision No. And Date	Comments
PMP 2080 EPP.013	Duties of the Individual Who Discovers an Emergency Condition	Revision 0 4-1-81	
EPP.014	Personnel Injury	Revision 0 10-27-81	
EPP.015	Responsibility of the On-Site Emergency Coordinator	Revision 1 4-29-82	TP-1,5-27-82 Exp NA
EPP Appendix A	Telephone Numbers for Key Plant Personnel	Revision 2 6-1-82	
EPP Appendix B	Hospital Assistance Plan	Revision 2 3-31-81	
EPP Appendix C	Radiological Supplement	Revision 0 4-1-81	

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

This temporary sheet applies to EMERGENCY PLAN ACTIVATION AND CONDITION CLASSIFICATION Instruction or Procedure No. PMP 2080 EPP 001 Revision No. 2	TEMPORARY SHEET NO. TP-1 Page 1 of 2
--	---

The following change () new requirement (X) shall be
instituted effective (Date) May 27, 1982.

REVISE SECTION 4.3 TO READ AS FOLLOWS:

- 4.3 Classify the Emergency Condition, using Exhibit A, according to the highest classification (Unusual Event, Alert, Site Emergency or General Emergency) the condition exceeds.
- 4.3.1 In the event of an Alert:
 - 4.3.1.1 Activation (via Step 4.4 below) of the Technical Support Center and Operations Staging Area is required.
- 4.3.2 In the event of a Site Emergency:
 - 4.3.2.1 Sound the Nuclear Emergency Alarm (NEA)
 - 4.3.2.2 Follow the NEA with a P.A. announcement indicating whether or not personnel are to evacuate.
 - 4.3.2.3 Activate (via Step 4.4 below) the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility.
- 4.3.3 In the event of a General Emergency:
 - 4.3.3.1 Sound the Nuclear Emergency Alarm (NEA)

This change should be made a permanent revision to the Instruction or Procedure:

☒ YES ☐ NO ☐ NOT KNOWN, additional review required

Expiration Date: <u>Procedure Revision</u> Originator: <u>Adrian Bean</u> Management Staff: <u>Adrian Bean</u> Senior Reactor Operator: <u>P. C. Craig</u> PNSRC: <u>Barbara</u> Date <u>6-2-82</u> Plant Manager: <u>E. L. Tandy</u> Date <u>6-2-82</u>	Standard Dist. List No.: _____ Distribution: _____
---	---

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to EMERGENCY PLAN ACTIVATION AND CONDITION CLASSIFICATION Instruction or Procedure No. PMP 2080 EPP 001 Revision No. 2</p>	<p>TEMPORARY SHEET NO. TP-1 Page 2 of 2</p>
<p>The following change () new requiremen (X) shall be instituted effective (Date) <u>May 27, 1982</u></p> <div style="margin-left: 100px;"><p>4.3.3.2 Follow the NEA with a P.A. announcement indicating whether or not personnel are to evacuate.</p><p>4.3.3.3 Recommend the Berrien County Sheriff's Department and Michigan State Police consider the following protective actions, as a minimum:</p><div style="margin-left: 40px;"><p>4.3.3.3.1 Activation of the Siren Warning System</p><p>4.3.3.3.2 Sheltering within a two-mile radius and five miles downwind</p><p>4.3.3.3.3 Placing cows within ten miles on stored feed, if appropriate</p></div><p>4.3.3.4 Activation (via Step 4.4 below) of the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility is required.</p></div>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u> Originator: <u>Noland Ryan</u> Management Staff: <u>Noland Ryan</u> Senior Reactor Operator: <u>P.C. Craig</u> PNSRC <u>[Signature]</u> Date <u>6-2-82</u> Plant Manager <u>E. J. Townley</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____ Distribution: _____</p>

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to RESPONSIBILITIES OF THE ON-SITE EMERGENCY COORDINATOR Instruction or Procedure No. PMP 2080 EPP 015 Revision No. 1</p>	<p>TEMPORARY SHEET NO.</p> <p>TP-1 Sheet 1 of 2</p>
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u>.</p> <p>REVISE EXHIBIT A, <u>ALERT</u>, STEP 5.4 TO READ AS FOLLOWS:</p> <p style="padding-left: 40px;">5.4 Activate the Technical Support Center and Operations Staging Area.</p> <p>REVISE EXHIBIT A, <u>SITE EMERGENCY</u>, STEP 5.4 TO READ AS FOLLOWS:</p> <p style="padding-left: 40px;">5.4 Activate the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility.</p> <p style="padding-left: 80px;">5.4.1 Sound the Nuclear Emergency Alarm and follow with a P.A. announcement indicating whether or not personnel are to evacuate.</p> <p>REVISE EXHIBIT A, <u>GENERAL EMERGENCY</u>, STEP 5.4 TO READ AS FOLLOWS:</p> <p style="padding-left: 40px;">5.4 Activate the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility.</p> <p style="padding-left: 80px;">5.4.1 Sound the Nuclear Emergency Alarm and follow with a P. A. announcement indicating whether or not personnel are to evacuate.</p> <p>REVISE EXHIBIT A, <u>GENERAL EMERGENCY</u>, STEP 5.11 TO READ AS FOLLOWS:</p> <p style="padding-left: 40px;">5.11 Recommend the Berrien County Sheriff's Department and Michigan State Police consider the following protective actions as a minimum:</p>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u></p> <p>Originator: <u>Donald Beggs</u></p> <p>Management Staff: <u>Donald Beggs</u></p> <p>Senior Reactor Operator: <u>P.C. Chang</u></p> <p>PNSRC: <u>Blakemore</u> Date <u>6-2-82</u></p> <p>Plant Manager: <u>E.L. Townley</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to <u>RESPONSIBILITIES OF THE ON-SITE</u> <u>EMERGENCY COORDINATOR</u> Instruction or Procedure No. <u>PMP 2080 EPP 015</u> Revision No. <u>1</u></p>	<p>TEMPORARY SHEET NO. TP - 1 Sheet 2 of 2</p>
---	--

The following change () new requirement (X) shall be
instituted effective (Date) May 27, 1982

- 5.11.1 Activation of the Siren Warning System
- 5.11.2 Sheltering within a two-mile radius and five miles downwind
- 5.11.3 Placing cows within ten miles on stored feed, if appropriate

This change should be made a permanent revision to the Instruction or Procedure:

☒ YES ☐ NO ☐ NOT KNOWN, additional review required

<p>Expiration Date: <u>Procedure Revision</u> Originator: <u>Arland Bean</u> Management Staff: <u>Arland Bean</u> Senior Reactor Operator: <u>P. C. Crang</u> PNSRC <u>Barbara</u> Date <u>6-2-82</u> Plant Manager <u>E. L. Townley</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____ Distribution: _____</p>
---	---

INDIANA & MICHIGAN POWER COMPANY
DONALD C. COOK NUCLEAR PLANT

PLANT MANAGER PROCEDURE

Index

Identification Number	Title	Revision No. And Date	Comments
PMP 2080 EPP.001	Emergency Plan Activation and Condition Classification	Revision 2 4-27-82	TP-1,5-27-82 Exp NA
EPP.002	Unusual Event	CANCELLED 10-29-81	
EPP.003	Alert	CANCELLED 10-29-81	
EPP.004	Site Emergency	CANCELLED 10-29-81	
EPP.005	General Emergency	CANCELLED 10-29-81	
EPP.006	Initial Dose Assessment (Gaseous)	Rev. 2 4-27-82	
EPP.007	Initial Release Assessments (Liquid)	Revision 0 4-1-81	TP-1,2-23-82 Exp NA
EPP.008	Calling Off-Duty Plant Personnel	Revision 1 4-29-82	TP-1,4-30-82 Exp N/A
EPP.009	Fire Emergency Guidelines	Revision 0 4-1-81	
EPP.010	Toxic Gas Release Guidelines	Revision 0 4-1-81	
EPP.011	Natural Emergency Guidelines	Revision 0 4-1-81	
EPP.012	Initial Off-Site Notification	Revision 1 4-27-82	

INDIANA & MICHIGAN POWER COMPANY
DONALD C. COOK NUCLEAR PLANT

PLANT MANAGER PROCEDURE

Index

Identification Number	Title	Revision No. And Date	Comments
PMP 2080 EPP.013	Duties of the Individual Who Discovers an Emergency Condition	Revision 0 4-1-81	
EPP.014	Personnel Injury	Revision 0 10-27-81	
EPP.015	Responsibility of the On-Site Emergency Coordinator	Revision 1 4-29-82	TP-1,5-27-82 Exp NA
EPP Appendix A	Telephone Numbers for Key Plant Personnel	Revision 2 6-1-82	
EPP Appendix B	Hospital Assistance Plan	Revision 2 3-31-81	
EPP Appendix C	Radiological Supplement	Revision 0 4-1-81	

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to EMERGENCY PLAN ACTIVATION AND CONDITION CLASSIFICATION Instruction or Procedure No. PMP 2080 EPP 001 Revision No. 2</p>	TEMPORARY SHEET NO. TP-1 Page 1 of 2
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u>.</p> <p>REVISE SECTION 4.3 TO READ AS FOLLOWS:</p> <p style="margin-left: 40px;">4.3 Classify the Emergency Condition, using Exhibit A, according to the highest classification (Unusual Event, Alert, Site Emergency or General Emergency) the condition exceeds.</p> <p style="margin-left: 40px;">4.3.1 In the event of an Alert:</p> <p style="margin-left: 80px;">4.3.1.1 Activation (via Step 4.4 below) of the Technical Support Center and Operations Staging Area is required.</p> <p style="margin-left: 40px;">4.3.2 In the event of a Site Emergency:</p> <p style="margin-left: 80px;">4.3.2.1 Sound the Nuclear Emergency Alarm (NEA)</p> <p style="margin-left: 80px;">4.3.2.2 Follow the NEA with a P.A. announcement indicating whether or not personnel are to evacuate.</p> <p style="margin-left: 80px;">4.3.2.3 Activate (via Step 4.4 below) the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility.</p> <p style="margin-left: 40px;">4.3.3 In the event of a General Emergency:</p> <p style="margin-left: 80px;">4.3.3.1 Sound the Nuclear Emergency Alarm (NEA)</p>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u></p> <p>Originator: <u>Adrian Beane</u></p> <p>Management Staff: <u>Adrian Beane</u></p> <p>Senior Reactor Operator: <u>P. C. Craig</u></p> <p>PNSRC: <u>Barbara</u> Date <u>6-2-82</u></p> <p>Plant Manager: <u>E. L. Tawney</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

This temporary sheet applies to EMERGENCY PLAN ACTIVATION AND CONDITION CLASSIFICATION Instruction or Procedure No. PMP 2080 EPP 001 Revision No. 2	TEMPORARY SHEET NO. TP-1 Page 2 of 2
--	--

The following change () new requirement (X) shall be
instituted effective (Date) May 27, 1982

- 4.3.3.2 Follow the NEA with a P.A. announcement indicating whether or not personnel are to evacuate.
- 4.3.3.3 Recommend the Berrien County Sheriff's Department and Michigan State Police consider the following protective actions, as a minimum:
 - 4.3.3.3.1 Activation of the Siren Warning System
 - 4.3.3.3.2 Sheltering within a two-mile radius and five miles downwind
 - 4.3.3.3.3 Placing cows within ten miles on stored feed, if appropriate
- 4.3.3.4 Activation (via Step 4.4 below) of the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility is required.

This change should be made a permanent revision to the Instruction or Procedure:

☒ YES ☐ NO ☐ NOT KNOWN, additional review required

Expiration Date: Procedure Revision
Originator: Nelson Bevan
Management Staff: Nelson Bevan
Senior Reactor Operator: P. C. Craig
PNSRC [Signature] Date 6-2-82
Plant Manager E. J. Townley Date 6-2-82

Standard Dist. List No.: _____
Distribution: _____

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to RESPONSIBILITIES OF THE ON-SITE Instruction or Procedure No. EMERGENCY COORDINATOR PMP 2080 EPP 015 Revision No. 1</p>	<p>TEMPORARY SHEET NO.</p> <p>TP-1 Sheet 1 of 2</p>
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u>.</p> <p>REVISE EXHIBIT A, <u>ALERT</u>, STEP 5.4 TO READ AS FOLLOWS:</p> <p style="margin-left: 40px;">5.4 Activate the Technical Support Center and Operations Staging Area.</p> <p>REVISE EXHIBIT A, <u>SITE EMERGENCY</u>, STEP 5.4 TO READ AS FOLLOWS:</p> <p style="margin-left: 40px;">5.4 Activate the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility.</p> <p style="margin-left: 80px;">5.4.1 Sound the Nuclear Emergency Alarm and follow with a P.A. announcement indicating whether or not personnel are to evacuate.</p> <p>REVISE EXHIBIT A, <u>GENERAL EMERGENCY</u>, STEP 5.4 TO READ AS FOLLOWS:</p> <p style="margin-left: 40px;">5.4 Activate the Technical Support Center, Operations Staging Area, Joint Public Information Center and Emergency Operations Facility.</p> <p style="margin-left: 80px;">5.4.1 Sound the Nuclear Emergency Alarm and follow with a P. A. announcement indicating whether or not personnel are to evacuate.</p> <p>REVISE EXHIBIT A, <u>GENERAL EMERGENCY</u>, STEP 5.11 TO READ AS FOLLOWS:</p> <p style="margin-left: 40px;">5.11 Recommend the Berrien County Sheriff's Department and Michigan State Police consider the following protective actions as a minimum:</p>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u></p> <p>Originator: <u>Richard Beggs</u></p> <p>Management Staff: <u>Richard Beggs</u></p> <p>Senior Reactor Operator: <u>P. C. Chang</u></p> <p>PNSRC: <u>Blanchard</u> Date <u>6-2-82</u></p> <p>Plant Manager: <u>E. L. Townley</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>

INDIANA & MICHIGAN
ELECTRIC COMPANY
DONALD C. COOK NUCLEAR PLANT

Instruction or Procedure Temporary Sheet

<p>This temporary sheet applies to RESPONSIBILITIES OF THE ON-SITE EMERGENCY COORDINATOR Instruction or Procedure No. PMP 2080 EPP 015 Revision No. 1</p>	<p>TEMPORARY SHEET NO. TP - 1 Sheet 2 of 2</p>
<p>The following change () new requirement (X) shall be instituted effective (Date) <u>May 27, 1982</u>.</p> <div style="margin-left: 40px;"><p>5.11.1 Activation of the Siren Warning System</p><p>5.11.2 Sheltering within a two-mile radius and five miles downwind</p><p>5.11.3 Placing cows within ten miles on stored feed, if appropriate</p></div>	
<p>This change should be made a permanent revision to the Instruction or Procedure:</p> <p><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NOT KNOWN, additional review required</p>	
<p>Expiration Date: <u>Procedure Revision</u></p> <p>Originator: <u>Arland Bevan</u></p> <p>Management Staff: <u>Arland Bevan</u></p> <p>Senior Reactor Operator: <u>P. C. Craig</u></p> <p>PNSRC: <u>Barbara</u> Date <u>6-2-82</u></p> <p>Plant Manager: <u>E. L. Townley</u> Date <u>6-2-82</u></p>	<p>Standard Dist. List No.: _____</p> <p>Distribution: _____</p>

INDIANA & MICHIGAN POWER COMPANY
DONALD C. COOK NUCLEAR PLANT

PLANT MANAGER PROCEDURE

Index

Identification Number	Title	Revision No. And Date	Comments
PMP 2080 EPP.001	Emergency Plan Activation and Condition Classification	Revision 2 4-27-82	TP-1,5-27-82 Exp NA
EPP.002	Unusual Event	CANCELLED 10-29-81	
EPP.003	Alert	CANCELLED 10-29-81	
EPP.004	Site Emergency	CANCELLED 10-29-81	
EPP.005	General Emergency	CANCELLED 10-29-81	
EPP.006	Initial Dose Assessment (Gaseous)	Rev. 2 4-27-82	
EPP.007	Initial Release Assessments (Liquid)	Revision 0 4-1-81	TP-1,2-23-82 Exp NA
EPP.008	Calling Off-Duty Plant Personnel	Revision 1 4-29-82	TP-1,4-30-82 Exp N/A
EPP.009	Fire Emergency Guidelines	Revision 0 4-1-81	
EPP.010	Toxic Gas Release Guidelines	Revision 0 4-1-81	
EPP.011	Natural Emergency Guidelines	Revision 0 4-1-81	
EPP.012	Initial Off-Site Notification	Revision 1 4-27-82	

INDIANA & MICHIGAN POWER COMPANY
DONALD C. COOK NUCLEAR PLANT

PLANT MANAGER PROCEDURE

Index

Identification Number	Title	Revision No. And Date	Comments
PMP 2080 EPP.013	Duties of the Individual Who Discovers an Emergency Condition	Revision 0 4-1-81	
EPP.014	Personnel Injury	Revision 0 10-27-81	
EPP.015	Responsibility of the On-Site Emergency Coordinator	Revision 1 4-29-82	TP-1,5-27-82 Exp NA
EPP Appendix A	Telephone Numbers for Key Plant Personnel	Revision 2 6-1-82	
EPP Appendix B	Hospital Assistance Plan	Revision 2 3-31-81	
EPP Appendix C	Radiological Supplement	Revision 0 4-1-81	