


THE CINCINNATI GAS & ELECTRIC COMPANY



CINCINNATI, OHIO 45201  
June 4, 1982  
QA-1803

E. A. BORGMANN  
SENIOR VICE PRESIDENT

U. S. Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Attention: Mr. J. G. Keppler  
Regional Administrator

RE: WM. H. ZIMMER NUCLEAR POWER STATION UNIT 1  
10CFR50.55(e)-ITEM M-42-ANCHOR DARLING VALVES  
WITH ANTI-ROTATIONAL DEVICES-DOCKET NO. 50-358  
CONSTRUCTION JOB E-5590 FILE NO. NRC-8 ITEM M-42

Gentlemen:

This letter constitutes an interim report concerning the subject condition, initially reported as a potentially reportable deficiency under 10CFR50.55(e).


CG&E Nonconformance Report #O-NPD-82-2140-E was generated which noted that motor operated Anchor-Darling Valves with anti-rotational devices were subject to operational failure if the set screw holding the stem collar in place should loosen.

This item is under investigation, and a report will be submitted by July 10, 1982.

We trust the above will be found acceptable as an interim report under 10CFR50.55(e).

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By   
E. A. BORGMANN  
SENIOR VICE PRESIDENT

FKP:plc

cc: NRC Senior Resident Inspector  
Attn: W. F. Christianson  
NRC Office of Inspection and Enforcement  
Washington, D. C. 20555

8206170279 820604  
PDR ADOCK 05000358  
S PDR

JE19  
JUN 11 1982