


THE CINCINNATI GAS & ELECTRIC COMPANY



CINCINNATI, OHIO 45201

E. A. BORGMANN  
SENIOR VICE PRESIDENT

June 11, 1982  
QA-1811

U. S. Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Attention: Mr. J. G. Keppler  
Regional Administrator

RE: Wm. H. ZIMMER NUCLEAR POWER STATION UNIT 1  
10CFR50.55(e) - ITEM E-19 - ELECTRICAL  
SEPARATION - DOCKET NO. 50-358 - CONSTRUCTION  
PERMIT NO. CPPR-88 - W.O. #57300 JOB E-5590  
FILE NO. NRC-7 E-19

Gentlemen:

This letter constitutes an interim report concerning the subject condition reported under the requirements of 10CFR50.55(e).

As a result of preliminary evaluations concerning electrical separation, CG&E has deemed that Item E-19 is reportable. The Architect-Engineer did not adequately translate applicable electrical separation criteria into the installation specifications and/or drawings for those items to be routed by the contractor. As a result, the site general contractor could not adequately develop all inclusive electrical separation inspection criteria.

Corrective Action Reports have been issued to the Architect-Engineer instructing him to adequately translate the design basis into the installation specifications. Further evaluation is required to properly assess proposed corrective action replies and the design basis for electrical separation to determine the proper corrective action to be taken. This evaluation and

8206170349 820611  
PDR ADOCK 05000358  
S PDR

JUN 14 1982

LE 27


Mr. J. G. Keppler  
Regional Administrator  
Region III  
June 11, 1982 - QA-1811  
Page 2

corrective action is expected to be completed by August 6, 1982.  
A final report will be submitted by August 16, 1982.

We trust the above will be found acceptable as an interim  
report under 10CFR50.55(e).

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By 

E. A. Borgmann  
Senior Vice President

EAB:aml

cc: NRC Office of Inspection & Enforcement  
Washington, D.C. 20555  
NRC Senior Resident Inspector  
Attn: W. F. Christianson