



LONG ISLAND LIGHTING COMPANY

SHOREHAM NUCLEAR POWER STATION

P.O. BOX 618, NORTH COUNTRY ROAD • WADING RIVER, N.Y. 11792

June 17, 1982

SNRC-715

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

SHOREHAM NUCLEAR POWER STATION - UNIT 1
Docket No. 50-322

Dear Mr. Denton:

This will confirm information given to the NRC staff by LILCO in a telephone conversation on May 14, 1982.

The switch used to initiate the standby liquid control system is safety related and it is mounted on a seismic category I panel.

The switch is G.E. type CR-2940 and the panel is no. 1H11* PNL603 (see FSAR figure 8.3.1-7).

If you require additional information, please do not hesitate to contact my office.

Very truly yours,

J. L. Smith
Manager, Special Projects
Shoreham Nuclear Power Station

RWG/gmm

cc: J. Higgins
E. Rossi
All Parties