

NRC REGION II
ATLANTA, GEORGIA

82 JUN 2 AID: 34

**Florida
Power**
CORPORATION

May 27, 1982
#3F-0582-27
File: 3-0-3-a-3

Mr. J. P. O'Reilly, Regional Administrator
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
101 Marietta Street N. W., Suite 3100
Atlanta, GA. 30303

SUBJECT: Crystal River Unit 3
Docket No. 50-302
Operating License No. DPR-72
IE Inspection Report Nos. 81-21 and 81-25

Dear Mr. O'Reilly:

Florida Power Corporation (FPC) has received and reviewed your confirmatory action letter of March 10, 1982. The actions that FPC will undertake are as stated in that letter, i.e., your understanding of FPC's actions is the same as our understanding. Those actions are:

1. Verify operability of fire dampers and perform subsequent inspections of safety-related dampers and fire doors in accordance with our existing procedures.
2. If any fire door or damper is found to be inoperable, the following action will be taken:
 - a. Establish a continuous fire watch on at least one side of the affected fire door or damper within one hour.
 - b. The continuous fire watch is to be maintained until such time that the inoperable fire door or damper is repaired.
3. Continue the above actions until the amended technical specifications have been approved by NRR. Changes to the above actions will have prior concurrence by NRC Region II prior to implementation.


8206220314 820527
PDR ADDCK 05000302
Q PDR

IE01

Mr. J. P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission, RII
Page -2-
May 27, 1982

In discussions with NRR, it was decided that FPC would not apply for any fire protection technical specification change until the Appendix R review for CR-3 was completed. The above actions will be performed by FPC until those changes are approved by NRR.

Very truly yours,

A handwritten signature in cursive script that reads "David G. Mardis".

David G. Mardis
Acting Manager
Nuclear Licensing


RMB/mlg

cc: Document Control Desk


STATE OF FLORIDA

COUNTY OF PINELLAS

D. G. Mardis states that he is the Acting Manager, Nuclear Licensing, of Florida Power Corporation; that he is authorized on the part of said company to sign and file with the Nuclear Regulatory Commission the information attached hereto; and that all such statements made and matters set forth therein are true and correct to the best of his knowledge, information, and belief.


D. G. Mardis

Subscribed and sworn to before me, a Notary Public in and for the State and County above named, this 28th day of May, 1982.


Notary Public

Notary Public, State of Florida at Large,
My Commission Expires: May 29, 1984