

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92072

H. B. RAY

STATION MANAGER

June 25, 1982

TELEPHONE
(714) 492-7700

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. R. H. Engelken, Regional Administrator

Dear Sir:

Subject: Docket No. 50-361
Licensee Event Report No. 82-016
San Onofre Nuclear Generating Station Unit 2

Reference: Letter, H.B. Ray (SCE) to R.H. Engelken (NRC),
dated June 1, 1982


This letter provides the follow-up to the referenced interim report which was made pursuant to Technical Specification Section 6.9.1.12.b. The reported event involves Limiting Condition for Operation (LCO) 3.8.3.1 and its associated Action Statements.

As stated in the referenced report, the performance of trouble shooting resulted in placing two 120VAC vital buses on their alternate sources, a condition not permitted by Limiting Condition for Operation (LCO) 3.8.3.1, nor addressed by its associated Action Statements. Although this violation of Technical Specifications was recognized and corrected within 10 minutes, a review of the nature of this violation by Station Management led to the conclusion that a thorough, independent evaluation and review was warranted. This independent review was conducted by an outside consultant.

June 25, 1982

Inasmuch as the referenced interim report described the Technical Specification violation and corrective measures must be described in the response to the Notice of Violation forwarded by your letter dated June 15, 1982 (received since the submittal of the referenced interim report), discussion of corrective action originally intended to be included in this report will be included in the response to the Notice of Violation. The response to the Notice of Violation is now scheduled to be submitted by July 14, 1982.

Sincerely,



cc: A. E. Chaffee (USNRC Resident Inspector, San Onofre Unit 2)

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement

U. S. Nuclear Regulatory Commission
Office of Management Information & Program Control

Institute of Nuclear Power Operations