

ROCHESTER GAS AND ELECTRIC CORPORATION

GINNA STATION

CONTROLLED COPY NUMBER _____

GINNA STATION
DATE: -
TIME: -

PROCEDURE NO. SC-602

REV. NO. 1

ALERT NOTIFICATION

TECHNICAL REVIEW

PORC REVIEW DATE 6-10-82

J. Malone
QC REVIEW

J. Malone
PLANT SUPERINTENDENT

6-15-82
EFFECTIVE DATE

QA X NON-QA _____ CATEGORY 1.0

REVIEWED BY: _____

THIS PROCEDURE CONTAINS 2 PAGES

82071202B4 820706
PDR ADDCK 05000244
F PDR

SC-602ALERT NOTIFICATION1.0 PURPOSE:

- 1.1 Provide information for the activation of the Emergency Response Plan at the Alert Level

2.0 REFERENCES:

- 2.1 SC-1 Radiation Emergency Plan
- 2.2 SC-200 Emergency Response Organization/Responsibilities
- 2.3 NUREG 0654

3.0 INSTRUCTIONS:

- 3.1 During normal working hours steps 3.2 through 3.3 may not be necessary.

- 3.2 Report we have an Alert based on _____ to
the following: (Initiating Condition)

(Speed Dial) (Manual Dial)

- 3.2.1 Plant Superintendent

If not available

- 3.2.2 Duty Engineer - see operations Plan of Day for phone number.

- 3.2.3 USNRC Resident Inspector

- 3.3 Notify Gas Dispatcher () to begin the Site Contingency Call List, SC-605.

- 3.4 Notify Security to activate Security Personnel Actions during a Radiation Emergency GS-10 ext. or page.

- 3.5 Report information on Notification Fact Sheet, Attachment I to SC-701, to the following:
- 3.5.1 New York State, Wayne and Monroe Counties, using NYS Hot Line,
-Press Button Allow 10 seconds
-Request roll call - New York State
Wayne County
Monroe County
This is Ginna Station
-Report information.
- If out of order
- New York State
- Wayne County
- Monroe County
- 3.5.2 USNRC Operations Officer using NRC RED PHONE (within one hour)
-when answered on other end report information
If out of order:
-Commercial Telephone to NRC -
Operations Center (via Bethesda Central Office).
-To NRC Operations Center
(via Silver Springs Central Office)
-To NRC Operator
(via Bethesda Central Office).
- 3.6 Report "We have an Alert based on _____ to the
following: (Initiating Condition)"
- 3.6.1 Vice President of Electric and Steam Production
- 3.6.2 Superintendent of Nuclear Production

ROCHESTER GAS AND ELECTRIC CORPORATION

GINNA STATION

CONTROLLED COPY NUMBER _____

PROCEDURE NO. SC-603

REV. NO. 1

SITE EMERGENCY NOTIFICATION

TECHNICAL REVIEW

PORC REVIEW DATE 6-10-82

QC REVIEW

PLANT SUPERINTENDENT

6-15-82
EFFECTIVE DATE

QA X NON-QA _____ CATEGORY 1.0

REVIEWED BY: _____

THIS PROCEDURE CONTAINS 2 PAGES

SC-603SITE EMERGENCY NOTIFICATION1.0 PURPOSE:

- 1.1 Provide information for the activation of the Emergency Response Plan at the Site Emergency Level.

2.0 REFERENCES:

- 2.1 SC-1 Radiation Emergency Plan
- 2.2 SC-200 Emergency Response Organization/Responsibilities
- 2.3 NUREG 0654

3.0 INSTRUCTIONS:

- 3.1 During normal working hours steps 3.2 through 3.3 may not be necessary.

- 3.2 If you completed SC-602 go to Step 3.5.

Report we have a Site Emergency based on _____ to
the following: (Initiating Condition)

(Speed Dial) (Manual Dial)
Ext.

- 3.2.1 Plant Superintendent -

If not available -

- 3.2.2 Duty Engineer - see operations Plan of Day for phone number.

- 3.2.3 USNRC Resident Inspector

- 3.3 Notify Gas Dispatcher to begin Site Contingency Call List SC-605.

- 3.4 Notify Security to activate Security Personnel Actions During A
Radiation Emergency GS-10 ext. _____ or page.

- 3.5 Report information on Notification Fact Sheet, Attachment I to SC-701, to the following:
- 3.5.1 New York State, Wayne and Monroe Counties, using NYS Hot Line,
-Press Button Allow 10 seconds
-Request roll call - New York State
Wayne County
Monroe County
This is Ginna Station
-Report information.
- If out of order
- New York State
- Wayne County
- Monroe County
- 3.5.2 USNRC Operations Officer using NRC RED PHONE (within one hour)
-when answered on other end report information
If out of order:
-Commercial Telephone to NRC -
Operations Center (via Bethesda Central Office).
-To NRC Operations Center
(via Silver Springs Central Office,
-To NRC Operator
(via Bethesda Central Office).
- 3.6 Report "We have a Site Emergency based on _____ to the following: (Initiating Condition)
- 3.6.1 Vice President of Electric and Steam Production
- 3.6.2 Superintendent of Nuclear Production
- 3.6.3 Westinghouse
Please activate your Emergency Response Plan.
- 3.6.4 INPO
Please activate your Emergency Response Plan.
- 3.7 If requested by Emergency Coordinator request radiological assistance from RAP team, Brookhaven

ROCHESTER GAS AND ELECTRIC CORPORATION

GINNA STATION

CONTROLLED COPY NUMBER _____

DATE: -
TIME: -

PROCEDURE NO. SC-604

REV. NO. 1

GENERAL EMERGENCY NOTIFICATION

TECHNICAL REVIEW

PORC REVIEW DATE 6-10-82

J. Brown
QC REVIEW

J. Moran
PLANT SUPERINTENDENT

6-15-82
EFFECTIVE DATE

QA X NON-QA _____ CATEGORY 1.0

REVIEWED BY: _____

THIS PROCEDURE CONTAINS 3 PAGES

SC-604GENERAL EMERGENCY NOTIFICATION1.0 PURPOSE:

- 1.1 Provide information for the activation of the Emergency Response Plan at the General Emergency Level.

2.0 REFERENCES:

- 2.1 SC-1 Radiation Emergency Plan
- 2.2 SC-200 Emergency Response Organization/Responsibilities
- 2.3 NUREG 0654

3.0 INSTRUCTIONS:

- 3.1 During normal working hours steps 3.2 through 3.3 may not be necessary.

- 3.2 If you completed SC-602 go to step 3.4.

Report we have a General Emergency based on _____ to
the following: (Initiating Condition

(Speed Dial) (Manual Dial)
Ext.

- 3.2.1 Plant Superintendent

If not available

- 3.2.2 Duty Engineer - see operations Plan of Day for phone number.

- 3.2.3 USNRC Resident Inspector

- 3.3 Notify Gas Dispatcher to begin Site Contingency Call List SC-605.

- 3.4 Go to step 3.5 if Security was notified of Site Emergency. Notify Security to activate Security Personnel Actions During A Radiation Emergency GS-10 ext. _____ or page.

- 3.5 Report information on Notification Fact Sheet, Attachment I to SC-701 to the following:
- 3.5.1 New York State, Wayne and Monroe Counties, using NYS Hot Line,
-Press Button Allow 10 seconds
-Request roll call - New York State
Wayne County
Monroe County
This is Ginna Station
-Report information.
- If out of order
- New York State
- Wayne County
- Monroe County
- 3.5.2 USNRC Operations Officer using NRC RED PHONE (within one hour)
-when answered on other end report information
If out of order:
-Commercial Telephone to NRC
Operations Center (via Bethesda Central Office).
-To NRC Operations Center
(via Silver Springs Central Office)
-To NRC Operator
(via Bethesda Central Office).
- 3.6 Report "We have a General Emergency based on _____ to the following: (Initiating Condition)
- 3.6.1 Vice President of Electric and Steam Production
- 3.6.2 Superintendent of Nuclear Production
- 3.6.3 Westinghouse
Please activate your Emergency Response Plan.
- 3.6.4 INPO
Please activate your Emergency Response Plan.
- 3.7 If requested by Emergency Coordinator request radiological assistance from RAP team, Brookhaven
- 3.8 Notify Radiation Management Corporation of General Emergency Condition.

3.9 Notify Plant Doctors of General Emergency condition and any medical problems

3.10 Notify the US Coast Guard of the General Emergency and to keep the Lake area near the plant clear of water traffic.