

POWER AUTHORITY STATE OF NEW YORK
PO BOX 215
BUCHANAN NY 10511

western union

Mailgram®



4-0375828195003 07/14/82 ICS IPMMTZZ CSP PHAB
2 9147398200 MGM TDMT BUCHANAN NY 07-14 0148P EST

NUCLEAR REGULATORY COMMISSION
ATTN RONALD C HAYNES DIRECTOR
REGION 1 OFFICE OF INSPECTION AND ENFORCEMENT
631 PARK AVE
KING OF PRUSSIA PA 19406

THIS IS A CONFIRMATION COPY OF A TELEGRAM ADDRESSED TO YOU
ON JULY 13 1982 WHILE IN THE COLD SHUTDOWN CONDITION DURING A
REFUELING OUTAGE TESTING OF PRESSURIZER SAFETY VALUES INDICATED THAT
THE SETPOINTS FOR VALVES PCV-466 AND PCV-468 WERE BELOW THE TECHNICAL
SPECIFICATION LIMIT OF 2485 PLUS/MINUS ONE PERCENT (TECHNICAL
SPECIFICATION 3.1.A.2.C.), THE SETPOINTS FOR VALVES PCV-466 AND 468
WERE FOUND TO BE 2370 AND 2435 PSIG RESPECTIVELY. RESIDENT INSPECTOR
T. KENNY WAS NOTIFIED AT 1200 HOURS ON JULY 14 1982. THIS TELEGRAM
SERVES AS THE 24 HOUR NOTIFICATION REQUIRED BY TECHNICAL
SPECIFICATION 6.9.1.7.B.

J. C. BRONS
RESIDENT MANAGER
INDIAN POINT #3 NUCLEAR POWER PLANT
PO BOX 215
BUCHANAN NY 10511
PO BOX 215
BUCHANAN NY 10511

13:52 EST

MGMCOMP

8207220540 820714
PDR ADCK 05000286
S PDR

IE29