

Iowa Electric Light and Power Company

July 29, 1982

DAEC-82- 503

Mr. James G. Keppler  
Regional Administrator  
Region III  
U. S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Subject: Prompt Notification of a  
Reportable Occurrence

File: A-118a

Dear Mr. Keppler:


This letter, telecopied to your office, is intended to satisfy the requirement for prompt notification of a Reportable Occurrence in accordance with Specification 6.11.2.a of the Duane Arnold Energy Center Technical Specifications.

Technical Specification paragraph(s) violated: 3.7.A.3.a

Description of Occurrence:

During normal operation surveillance testing, differential pressure switches PDS-4304 and 4305 tripped out-of spec high at 0.65 and 0.7 psid, respectively. Technical Specification 3.7.A.3.a requires the setpoints to be 0.5 psid. PDS-4304 and 4305 provide opening signals for the torus to reactor building vacuum breakers CV-4304 and CV-4305, respectively. The pressure switches were immediately recalibrated and functionally tested satisfactory.

Very truly yours,



Daniel L. Mineck  
Plant Superintendent - Nuclear  
Duane Arnold Energy Center

DLM/KLH /p1

cc: NRC Resident Inspector

AUG 4 1982

8208100045 820729  
PDR ADOCK 05000331  
S PDR

PE 29