

NORTHEAST UTILITIES

THE CONNECTICUT LIGHT AND POWER COMPANY
WESTERN MASSACHUSETTS ELECTRIC COMPANY
HOLYOKE WATER POWER COMPANY
NORTHEAST UTILITIES SERVICE COMPANY
NORTHEAST NUCLEAR ENERGY COMPANY

General Offices • Selden Street, Berlin, Connecticut

P.O. BOX 270
HARTFORD, CONNECTICUT 06141-0270
(203) 665-5000

February 26, 1990

Docket No. 50-423

B13453

Re: IE Inspection Report 50-423/89-14

Mr. W. T. Russell
Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

- References:
- (1) E. J. Mroczka letter to W. T. Russell, Response to Notice of Violation, Inspection Report 50-423/89-14, dated November 17, 1989.
 - (2) E. J. Mroczka letter to the U.S. Nuclear Regulatory Commission, Systematic Assessment of Licensee Performance, dated February 21, 1990.

Gentlemen:

Millstone Nuclear Power Station, Unit No. 3
Steam Generator Blowdown Radiation Monitor


In Reference (1), Northeast Nuclear Energy Company (NNECO) provided a response that described the reasons for failure to repair the steam generator blowdown radiation monitor in a timely manner and outlined to the NRC a plan for restoring the monitor to service. Specifically, NNECO indicated that the design changes to the system and restoring the monitor to service will be accomplished by February 28, 1990 (References (1) and (2)).

Modifications to the steam generator blowdown sample system were completed this week. System Operation will be evaluated for the next two weeks to ensure that the monitor is operating reliably. Then, NNECO, intends to declare the monitor operable.

If you have any questions regarding the information contained in this letter, please contact us.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY



E. J. Mroczka
Senior Vice President

IEO
1/0

Mr. W. T. Russell
B13453/Page 2
February 26, 1990

cc: D. H. Jaffe, NRC Project Manager, Millstone Unit No. 3
W. J. Raymond, Senior Resident Inspector, Millstone Unit Nos. 1, 2, and 3

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555