

**Omaha Public Power District**  
1623 Harney Omaha, Nebraska 68102-2247  
402/536-4000

June 29, 1990  
LIC-90-0569

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Station P1-137  
Washington, DC 20555

- REFERENCES:
1. Docket No. 50-285
  2. Letter from OPPD (K. J. Morris) to NRC (Document Control Desk) dated October 27, 1989 (LIC-89-962)
  3. Letter from OPPD (K. J. Morris) to NRC (Document Control Desk) dated December 22, 1989 (LIC-89-1159)

Gentlemen:

SUBJECT: Follow-up Report on Inoperability of Fire Barriers

Omaha Public Power District (OPPD) reported in Reference 3 that inoperable fire door 1013-7 would be restored to operable status by June 29, 1990, at which time a follow-up report would be submitted. This report is submitted to inform you that repairs to fire door 1013-7 have not been completed as originally expected due to problems encountered during door replacement.

Fire door 1013-7 is installed in a pyrocrete enclosure and replacement work for this door involves removal of part of the pyrocrete wall that surrounds the door opening. When the door replacement began and the pyrocrete was removed it was discovered that the new door and frame assembly could not be installed to the requirements of the Underwriters Laboratory (U.L.) listing, due to the configuration of the structural steel forming the door opening. An engineering design change had to be prepared to modify the steel framing around the door opening to accept the new door frame in accordance with its U.L. listing.

9007050025 900629  
PDR ADOCK 05000285  
S PDC

IE22  
1/0

Replacement work for Door 1013-7 is presently in progress and is expected to be complete by August 1, 1990. Compensatory measures have been in place for the entire time period this door has been inoperable and will remain in place until the door can be restored to an operable status.

If you have any questions, please contact me.

Sincerely,

*W. G. Gates*

W. G. Gates  
Division Manager  
Nuclear Operations

WGG/sel

c: LeBoeuf, Lamb, Leiby & MacRae  
A. Bournia, NRC Project Manager  
R. D. Martin, NRC Regional Administrator, Region IV  
P. H. Harrell, NRC Senior Resident Inspector