


Alabama Power Company  
40 Inverness Center Parkway  
Post Office Box 1295  
Birmingham, Alabama 35201  
Telephone 205 868-5581

W. G. Hairston, III  
Senior Vice President  
Nuclear Operations

July 2, 1990



Docket No. 50-364


U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D. C. 20555

Joseph M. Farley Nuclear Plant - Unit 2  
Special Report No. 90-006, Radiation Monitor  
Inoperable For More Than Seven Days

Gentlemen:

In accordance with the requirements of Technical Specification 3.3.3.1, the enclosed Special Report No. 90-006, Unit 2, is submitted.

Respectfully submitted,

  
W. G. Hairston, III

WGH,III/JAR:mgd 18.1.32

Enclosure

cc: Mr. S. D. Ebnetter  
Mr. S. T. Loffman  
Mr. G. F. Maxwell

9007090020 900702  
PDR ADCK 05000364  
S FDC

*IFED*  
*11*

**Special Report No. 90-006, Unit 2  
Radiation Monitor Inoperable For More Than Seven Days**

At 1730 on 06/15/90, radiation monitor R-60A (Main Steam Relief and Atmospheric Steam Dump Discharge) was declared inoperable due to erroneous indication. Troubleshooting isolated the problem to the detector which is accessible only during cold shutdown. This monitor is scheduled to be repaired during the next outage of sufficient duration.

Technical Specification 3.3.3.1 requires this monitor to be returned to operable status within 7 days or a Special Report must be submitted within the next 14 days. Therefore, this Special Report is being submitted.

All Technical Specification action statement requirements are being met for this radiation monitor.

REM:mgd 22.03