

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

5N 157B Lookout Place

JUL 12 1990

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of)
Tennessee Valley Authority)

Docket No. 50-260

BROWNS FERRY NUCLEAR PLANT (BFN) - UNIT 2 - NRC BULLETIN NO. 88-03 INSPECTION RESULTS

- References:
1. NRC Bulletin No. 88-03: Inadequate Latch Engagement in HFA Type Latching Relays Manufactured by General Electric (GE) Company, dated March 10, 1988
 2. TVA letter to NRC dated July 6, 1988, "Tennessee Valley Authority (TVA) - Nuclear Regulatory Commission (NRC) Bulletin 88-03, Inadequate Latch Engagement in HFA-Type Latching Relays Manufactured by General Electric (GE) Company"

This letter provides the results of the BFN Unit 2 inspections, as required by Reference 1 and as committed to by TVA in Reference 2. A total of 61 HFA relays were inspected, 14 of which were contained in spare compartments. The result of these inspections is that none of the relays were found to have inadequate latch engagement. Therefore, no corrective repairs or replacement of these relays were required.


Plant procedures are in place to require a complete calibration and latch engagement inspection prior to placing new or spare HFA relays into service.

This completes the actions requested and reporting requirements for BFN Unit 2 HFA relays.

If there are any questions concerning this response, please call Patrick P. Carrier at (205) 729-3570.

Very truly yours,

TENNESSEE VALLEY AUTHORITY



E. G. Wallace, Manager
Nuclear Licensing and
Regulatory Affairs

cc: See page 2

9007180153 900712
PDR ADJCK 05000260
Q FDC

TEI
110

JUL 12 1990

U.S. Nuclear Regulatory Commission

cc Ms. S. C. Black, Deputy Director
Project Directorate II-4
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike,
Rockville, Maryland 20852

NRC Resident Inspector
Browns Ferry Nuclear Plant
Route 12, Box 637
Athens, Alabama 35609-2000

Thierry M. Ross, Project Manager
U. S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 208

Mr. B. A. Wilson, Project Chief
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323