

LICENSEE EVENT REPORT

CONTROL BLOCK 1 2 3 4 5 6

(PLEASE PRINT ALL REQUIRED INFORMATION)

FACILITY NAME						LICENSE NUMBER						LICENSE TYPE				EVENT TYPE								
01	M	N	M	N	P	1	0	0	-	0	0	0	0	-	0	0	4	1	1	1	1	0	1	
7	8	9				14	15										25	26					31	32
CATEGORY		REPORT TYPE		REPORT SOURCE		DOCKET NUMBER						EVENT DATE				REPORT DATE								
01	CON	1	T	L	0	5	0	-	0	2	6	3	0	9	1	6	7	7	1	1	1	8	7	7
7	8		57	58	59	60	61						68	69						74	75			80

EVENT DESCRIPTION

03 During local leak rate test, HPCI-9, turbine exhaust line check valve was leaking

04 in excess of technical specification acceptance criteria. Valve seats cleaned

04 and lapped. Retested satisfactory. Similar previous events (M-RO-77-24-4)

05

06

SYSTEM CODE		CAUSE CODE		COMPONENT CODE				PRIME COMPONENT SUPPLIER		COMPONENT MANUFACTURER				VIOLATION	
07	S	D	E	V	A	L	V	E	X	A	3	9	5	Y	
7	8	9	10	11	12				17	43				47	48

CAUSE DESCRIPTION

08 Anchor Valve Co. 16"-150 lb swing check valve. Failed test due to accumulated dirt

09 on seating surfaces. Seats cleaned and lapped. Retested satisfactory.

10

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION						
11	H	0	0	0	NA	B	NA							
7	8	9	10	12	13	44	45	46	80					
FORM OF ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE								
12	Z	Z	NA			NA								
7	8	9	10	11		44	45	80						

PERSONNEL EXPOSURES

NUMBER		TYPE		DESCRIPTION	
13	0	0	Z	NA	
7	8	9	11	12	13

PERSONNEL INJURIES

NUMBER		DESCRIPTION	
14	0	NA	
7	8	9	12

OFFSITE CONSEQUENCES

15 NA

LOSS OR DAMAGE TO FACILITY

TYPE		DESCRIPTION	
16	Z	NA	
7	8	9	10

PUBLICITY

17 NA

ADDITIONAL FACTORS

18 NA

19

NAME D E Pedersen

PHONE 612/295-5151

9102130560 771118
CF ADDCK 05000263
CF

CPD 881-887