

ATTACHMENT A

Revised June 1993

Operating Status

SONGS Unit 2 Monthly Operating Report

mor.jul/14

9308170185 930813
PDR ADOCK 05000361
R PDR

NRC MONTHLY OPERATING REPORT
 ***Revised data is in **BOLD** Type ***

DOCKET NO: 50-361
 UNIT NAME: SONGS - 2
 DATE: _____
 COMPLETED BY: J. L. Darling
 TELEPHONE: (714) 368-6223

OPERATING STATUS

1.	Unit Name: <u>San Onofre Nuclear Generating Station, Unit 2</u>		
2.	Reporting Period: <u>June 1993</u>		
3.	Licensed Thermal Power (Mwt): <u>3390</u>		
4.	Nameplate Rating (Gross MWe): <u>1127</u>		
5.	Design Electrical Rating (Net MWe): <u>1070</u>		
6.	Maximum Dependable Capacity (Gross MWe): <u>1127</u>		
7.	Maximum Dependable Capacity (Net MWe): <u>1070</u>		
8.	If Changes Occur In Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons: <u>NA</u>		
9.	Power Level To Which Restricted, If Any (Net MWe): <u>NA</u>		
10.	Reasons For Restrictions, If Any: <u>NA</u>		

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	<u>720.00</u>	<u>4,343.00</u>	<u>86,520.00</u>
12. Number Of Hours Reactor Was Critical	<u>96.73</u>	<u>3,719.73</u>	<u>64,454.09</u>
13. Reactor Reserve Shutdown Hours	<u>0.00</u>	<u>0.00</u>	<u>0.00</u>
14. Hours Generator On-Line	<u>96.62</u>	<u>3,719.62</u>	<u>63,376.89</u>
15. Unit Reserve Shutdown Hours	<u>0.00</u>	<u>0.00</u>	<u>0.00</u>
16. Gross Thermal Energy Generated (MWH)	<u>272,151.65</u>	<u>12,281,788.01</u>	<u>207,101,636.33</u>
17. Gross Electrical Energy Generated (MWH)	<u>96,503.50</u>	<u>4,149,548.00</u>	<u>70,195,108.00</u>
18. Net Electrical Energy Generated (MWH)	<u>87,248.96</u>	<u>3,946,550.96</u>	<u>66,554,066.79</u>
19. Unit Service Factor	<u>13.42%</u>	<u>85.65%</u>	<u>73.25%</u>
20. Unit Availability Factor	<u>13.42%</u>	<u>85.65%</u>	<u>73.25%</u>
21. Unit Capacity Factor (Using MDC Net)	<u>11.33%</u>	<u>84.93%</u>	<u>71.89%</u>
22. Unit Capacity Factor (Using DER Net)	<u>11.33%</u>	<u>84.93%</u>	<u>71.89%</u>
23. Unit Forced Outage Rate	<u>0.00%</u>	<u>0.00%</u>	<u>6.50%</u>
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): Refueling shutdown, June 5, 1993, forecast duration (86 days)			
25. If Shutdown At End Of Report Period, Estimated Date of Startup:		<u>NA</u>	
26. Units In Test Status (Prior To Commercial Operation):	Forecast		Achieved

INITIAL CRITICALITY	<u>NA</u>	<u>NA</u>
INITIAL ELECTRICITY	<u>NA</u>	<u>NA</u>
COMMERCIAL OPERATION	<u>NA</u>	<u>NA</u>