



GPU Nuclear Corporation
Route 441 South
P.O. Box 480
Middletown, Pennsylvania 17057-0480
(717) 944-7621
Writer's Direct Dial Number:
(717) 948-8005

August 24, 1993
C311-93-2110

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Dear Sir:


Subject: Three Mile Island Nuclear Station, Unit 1 (TMI-1)
Operating License No. DPR-50,
Docket No. 50-289
Technical Specification Change Request No. 231

In accordance with 10 CFR 50.4 (b) (1), enclosed is Technical Specification Change Request No. 231.

Also enclosed is one signed copy of the Certificate of Service for this request which confirms service to the chief executives of the township and county in which the facility is located, as well as the Commonwealth of Pennsylvania, Bureau of Radiation Protection.

The proposed amendment adopts the provision of the Standard Technical Specifications (STS) which allows a period of 24 hours to complete a surveillance requirement upon discovery that the surveillance has been missed. The basis for the delay period includes, among other considerations, the safety significance of the delay in completing the required surveillance and the recognition that the most probable result of any particular surveillance being performed is the successful verification of conformance with the requirements.

Sincerely,


T. G. Broughton
Vice President and Director, TMI-1

MRK/emf

Enclosures: 1) Technical Specification Change Request No. 231
2) Certificate of Service for Technical Specification Change Request No. 231

cc: Region I Administrator
TMI-1 Senior Project Manager
TMI Senior Resident Inspector

GPU Nuclear Corporation is a subsidiary of General Public Utilities Corporation

9308270035 930824
PDR ADDCK 05000289
PDR

00051

A001
111