



Kevin P. Riley
Nuclear Support Services Manager
Harris Nuclear Plant
5413 Shearon Harris Rd
New Hill, NC 27562-9300

984.229.2124

February 25, 2020
Serial: RA-20-0044

ATTN: Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Shearon Harris Nuclear Power Plant, Unit 1
Docket No. 50-400/Renewed License No. NPF-63

Subject: Annual Report in Accordance with Technical Specification 6.9.1.2

Ladies and Gentlemen:

In accordance with Shearon Harris Nuclear Power Plant, Unit 1 (HNP), Technical Specification 6.9.1.2, Duke Energy Progress, LLC, is providing the following information regarding reactor coolant specific activity for 2019.

During 2019, specific activity of the HNP reactor coolant did not exceed 1 microCurie per gram dose equivalent I-131 or 100/E-bar microCuries per gram of gross radioactivity as set forth in Technical Specification 3.4.8.

This submittal contains no regulatory commitments. Please refer any questions regarding this submittal to Dennis Earp at (984) 229-2673.

Sincerely,

A handwritten signature in black ink, appearing to read "KPR", written over a horizontal line.

Kevin P. Riley

cc: J. Zeiler, NRC Sr. Resident Inspector, HNP
T. Hood, NRC Project Manager, HNP
NRC Regional Administrator, Region II