

BEFORE THE UNITED STATES  
NUCLEAR REGULATORY COMMISSION

In the matter of )  
NEW YORK POWER AUTHORITY ) Docket No. 50-333  
James A. FitzPatrick Nuclear Power Plant )


APPLICATION FOR AMENDMENT TO OPERATING LICENSE

The New York Power Authority requests an amendment to the Technical Specifications contained in Appendix A to Facility Operating License DPR-59 for the James A. FitzPatrick Nuclear Power Plant. This application is filed in accordance with Section 10 CFR 50.90 of the Nuclear Regulatory Commission's regulation.

This application for an amendment to the James A. FitzPatrick Technical Specifications requests an extension to the surveillance interval for calibrating the pressure switches which sense main turbine control valve fast closure. The Authority is requesting an extension for this surveillance interval requirement until the fall maintenance outage, currently scheduled to start on October 23, 1993.

The proposed change to the Technical Specifications is Attachment I to this Application for Amendment to the Operating License. The Safety Evaluation for the proposed change is included as Attachment II.

New York Power Authority

  
Ralph E. Beedle  
Executive Vice President  
Nuclear Generation

STATE OF NEW YORK  
COUNTY OF WESTCHESTER

Subscribed and sworn to before me  
this 26<sup>th</sup> day of August 1993.

  
Notary Public

KATHLEEN D. GALLAGHER  
Notary Public, State of New York  
No. 5009481  
Qualified in Westchester County  
Commission Expires Nov. 16, 1994