



Northern States Power Company

414 Nicollet Mall
Minneapolis, Minnesota 55401-1927
Telephone (612) 330-5500

August 25, 1993

10 CFR Part 50
Section 50.55a(f)

U S Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
Docket Nos. 50-282 License Nos. DPR-42
50-306 DPR-60

Submittal of Revision 2 of the 3rd 10-Year Inservice
Testing (IST) Program to the Requirements of ASME Section XI

Attached is the ASME Code Section XI Inservice Testing (IST) Program, Revision 2 for the third ten-year interval for Units 1 and 2 of the Prairie Island Nuclear Generating Plant. We had originally (June 16, 1993) submitted for review an earlier version of the IST Program. The changes between the earlier version and this one are indicated by sidebars.

The Program is being developed to the following specific revisions of the Code: ASME Section XI, 1989 Edition; ASME/ANSI OM, OMa-1988 Addenda to the OM-1987 Edition. We are invoking the positions stated in Generic Letter 89-04 in the development of the Program. In addition, we assume the Generic Letter guidance is also applicable to OM 6 and OM 10. Alternate forms of testing that conform to the requirements of Attachment 1 of the Generic Letter have been included in the Program without a Request for Relief and are documented in the Plant IST Program Plan, H10.1.

The Unit 1 portion of this Program will become effective on December 16, 1993 and the Unit 2 portion will become effective on December 21, 1994.

We will provide you with updates to the Inservice Testing Program Manual for information when significant revisions have been incorporated (e.g., the addition of new components because of a significant modification to the plant). Future Requests for Relief will be submitted if the need occurs.

020064

9309020159 930825
PDR ADDCK 05000282
P PDR

A047

US NRC
August 25, 1993
Page 2

Please contact Jack Leveille (612-388-1121, Ext. 4662) if you have any questions related to this letter.



Roger O Anderson
Director
Licensing and Management Issues

c: Regional Administrator - Region III, NRC
Senior Resident Inspector, NRC
NRR Project Manager, NRC
J E Silberg
A S Jimenez (Hartford)
H Baron (State of Minnesota)

Attachments: INSERVICE TESTING PROGRAM MANUAL, Rev. 2

PI Operations Manual Section H10.1, Rev. 2, Table 1, "ASME
Section XI Valves, Unit 1"

PI Operations Manual Section H10.1, Rev. 2, Table 2, "ASME
Section XI Valves, Unit 2"

PI Operations Manual Section H10.1, Rev. 2, Appendix B, "Unit 1
Deferral Notes"

PI Operations Manual Section H10.1, Rev. 2, Appendix C, "Unit 2
Deferral Notes"

PI Operations Manual Section H10.1, Rev. 2, Appendix D, "IST
Section Valve Notes"