

August 27, 1993

SM2-L93-0096

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

RE: Nine Mile Point Unit 2
Docket No. 50-410
NPF-69
TAC No. M86610

Gentlemen:

Niagara Mohawk Power Corporation hereby transmits an Application for Amendment to Nine Mile Point Unit 2 Operating License NPF-69. This application supersedes our application of March 30, 1993 (NMP2L 1374). Also enclosed are the proposed changes to the Technical Specifications in Appendix A of the above mentioned license. Supporting information and analyses demonstrating that the proposed changes involve no significant hazards consideration pursuant to 10CFR50.92 are included in Appendix B.

The proposed Technical Specification changes contained herein represent a revision to Specification 4.8.1.1.2.e "AC Sources - Operating" and adds Specification 4.8.1.1.2.f. These will replace the requirement to perform a hot Loss of Off-Site Power test following the 24 hour full power run during shutdown (4.8.1.1.2.e.8) with a requirement to perform a hot restart test following a full loaded diesel run of greater than 2 hours in any operating condition (4.8.1.1.2.f). Also, current Sections 4.8.1.1.2.f and g are relettered to 4.8.1.1.2.g and h. The proposed changes are consistent with the Improved Standard Technical Specifications, NUREG-1434 issued September 28, 1992, and previously approved Technical Specification Amendment No. 13 for Seabrook. In order to support the upcoming Nine Mile Point Unit 2 refueling outage, approval of this application is requested by October 1, 1993.

Pursuant to 10CFR50.91(b)(1), Niagara Mohawk has provided a copy of this license amendment request and the associated analyses regarding no significant hazards consideration to the appropriate state representative.

Sincerely,



C. D. Terry
Vice President
Nuclear Engineering

MC/lmc

Enclosures

xc: Regional Administrator, Region I
Mr. W. L. Schmidt, Senior Resident Inspector
Mr. R. A. Capra, Director, Project Directorate I-A, NRR
Mr. J. E. Menning, Project Manager, NRR
Ms. Donna Ross
Division of Policy Analysis and Planning
New York State Energy Office
Agency Building 2
Empire State Plaza
Albany, New York 12223
Records Management