

UNITED STATES NUCLEAR REGULATORY COMMISSION

In the Matter of)
)
Niagara Mohawk Power Corporation) Docket No. 50-410
)
Nine Mile Point Nuclear Station Unit 2)

APPLICATION FOR AMENDMENT TO OPERATING LICENSE


Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission, Niagara Mohawk Power Corporation, holder of Facility Operating License No. NPF-69, hereby requests that section 4.8.1.1.2 of the Technical Specifications set forth in Appendix A to the License be amended. These proposed changes have been reviewed in accordance with Section 6.5 of the Technical Specifications.

The proposed Technical Specification changes are set forth in Attachment A to this application. These changes will replace the requirement to perform a hot Loss of Off-Site Power test following the 24 hour full power run during shutdown (4.8.1.1.2.e.8) with a requirement to perform a hot restart test following a full loaded diesel run of greater than 2 hours in any operating condition (4.8.1.1.2.f). Also, current Sections 4.8.1.1.2.f and g are relettered to 4.8.1.1.2.g and h. The proposed changes will not authorize any change in the types of effluents or in the authorized power level of the facility in conjunction with this Application for License Amendment. Supporting information and analyses which demonstrate that the proposed changes involve no significant hazards consideration pursuant to 10CFR50.92, are included as Attachment B.


Wherefore, applicant respectfully requests that Appendix A to Facility Operating License No. NPF-69 be amended in the form attached hereto as Attachment A.

NIAGARA MOHAWK POWER CORPORATION

By


C. D. Terry
Vice President
Nuclear Engineering

Subscribed and Sworn to before me
on this 27th day of August, 1993


NOTARY PUBLIC

REBECCA F. PURDUM
Notary Public, State of New York
No. 4956408
Qualified in Wayne County
Commission Expires August 28, 1995

9309020227 930827
PDR ADDCK 05000410
P PDR