



P.O. Box 300
Seabrook, NH 03874
Telephone (603) 474-9521
Facsimile (603) 474-2987

Ted C. Feigenbaum
Senior Vice President and
Chief Nuclear Officer

NYN- 93117

August 25, 1993

United States Nuclear Regulatory Commission
Washington, D.C. 20555

Attention: Document Control Desk

Reference: Facility Operating License No. NPF-86, Docket No. 50-443

Subject: 1992 Steam Generator Inservice Inspection

Gentlemen:

North Atlantic Energy Service Corporation (North Atlantic) completed the second inservice inspection of the Seabrook Station steam generators during September 1992. Steam Generators A and D were included in this inspection. The enclosed report is submitted pursuant to Technical Specification Surveillance Requirement 4.4.5.5b. The enclosed report contains the following information as required by Surveillance Requirement 4.4.5.5b:

The number and extent of tubes inspected,

The location and percent of wall thickness penetration for each indication of an imperfection,

Identification of tubes plugged.

No tubes were required to be plugged as a result of eddy current inspection. However, one Inconel 600 plug was removed and replaced with an Inconel 690 plug. The hot leg plug was replaced pursuant to NRC Bulletin No. 89-01 and Westinghouse WCAP-12244.

If you have any questions concerning the enclosed report, please contact Mr. James Peschel, Regulatory Compliance Manager, at (603) 474-9521 extension 3772.

Very truly yours,

A handwritten signature in dark ink, appearing to read "Ted C. Feigenbaum".
Ted C. Feigenbaum

TCF:MDO/act

Enclosure

311112

a member of the Northeast Utilities system

9309020251 930825
PDR ADOCK 05000443
G PDR

A047
11

United States Nuclear Regulatory Commission
Attention: Document Control Desk

August 25, 1993
Page two

cc: Mr. Thomas T. Martin
Regional Administrator
U. S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Mr. Albert W. De Agazio, Sr. Project Manager
Project Directorate I-4
Division of Reactor Projects
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. Noel Dudley
NRC Senior Resident Inspector
P.O. Box 1149
Seabrook, NH 03874

North Atlantic
August 25, 1993

ENCLOSURE TO NYN-93117