

PHILADELPHIA ELECTRIC COMPANY

NUCLEAR GROUP HEADQUARTERS

955-65 CHESTERBROOK BLVD.

WAYNE, PA 19087-5691

(215) 640-6000

STATION SUPPORT DEPARTMENT

August 25, 1993

Docket Nos. 50-352
50-353License Nos. NPF-39
NPF-85U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555Subject: Limerick Generating Station, Units 1 and 2
Technical Specifications Change Request

Gentlemen:

Philadelphia Electric Company (PECo) is submitting Technical Specifications (TS) Change Request No. 93-01-0, in accordance with 10 CFR 50.90, requesting an amendment to the TS (Appendix A) of Operating License Nos. NPF-39 and NPF-85 for Limerick Generating Station (LGS), Units 1 and 2, respectively. This proposed TS change involves revising TS Surveillance Requirement (SR) 4.5.1 to reduce the frequency for venting the Emergency Core Cooling System (ECCS) piping from once every 31 days to once every six (6) months. Information supporting this TS Change Request is contained in Attachment 1 to this letter, and the proposed replacement pages for the LGS, Units 1 and 2, TS are contained in Attachment 2.

We request that, if approved, the amendments to the LGS, Units 1 and 2, TS be effective immediately.

If you have any questions, please do not hesitate to contact us.

Very truly yours,

G. A. Hunger, Jr.
G. A. Hunger, Jr.
Director
Licensing Section

02002

Attachments

cc: T. T. Martin, Administrator, Region I, USNRC (w/ attachments)
N. S. Perry, USNRC Senior Resident Inspector, LGS (w/ attachments)
W. P. Dornsife, Director, PA Bureau of Radiological Protection
(w/ attachments)

9309030179 930825
PDR ADDCK 05000352
P PDR


A001
11/1

COMMONWEALTH OF PENNSYLVANIA :


COUNTY OF CHESTER :

D. R. Helwig, being first duly sworn, deposes and says:

That he is Vice President of Philadelphia Electric Company; that he has read the foregoing Technical Specifications (TS) Change Request No. 93-01-0, for Limerick Generating Station, Units 1 and 2, concerning the proposed changes to TS Surveillance Requirements to reduce the frequency for venting the Emergency Core Cooling System (ECCS) piping from once every 31 days to once every six (6) months, and knows the contents thereof; and that the statements and matters set forth therein are true and correct to the best of his knowledge, information, and belief.


Vice President

Subscribed and sworn to
before me this 19th day
of August 1993.


Notary Public

Notarial Seal
Eric A. Santon, Notary Public
Tredyffrin Twp., Chester County
My Commission Expires July 10, 1995