

QUARTERLY RELEASE REPORT

QUARTER: 1 and 2 YEAR: 1989

The following composite sample results were calculated as "Less Than" values greater than the LLD values specified by Technical Specification of $5.0\text{E-}08$ uCi/ml Sr-89 for liquid. The Curie amounts released and the corresponding doses were calculated to be zero.

Liquid Composite Sample Results

RELEASE PATH	QTR 1 uCi/ml	QTR 2 uCi/ml
UI TBS	<1.2E-07	
UII TBS	<1.2E-07	
UI SGBD	<1.2E-07	
UII SGBD	<1.2E-07	
WASTE TANKS	<6.0E-08	
UI COND		
UII COND		